



ITEMS IN RED NOT SUPPLIED BY HENDRIX

ITEM	DESCRIPTION	QTY	DESIGN PARAMETERS
1	MESSENGER BRACKET, HENDRIX TYPE BM-14	1	15kV
2	INSULATOR, PIN TYPE, HENDRIX HPI-15VTP	1	LINE ANGLES: 0-6°
3	INSULATOR PIN, HENDRIX SSP-2	1	ELEVATION CHANGE: 20°
4	HENDRIX AERIAL CABLE,(SIZE AND VOLTAGE RATING AS REQ.)	AS REQ	TITLE
5	MESSENGER, (SIZE AND TYPE AS REQUIRED)	AS REQ	STEEP GRADE CONSTRUCTION USING BM-14
6	MACHINE BOLT, 5/8" X REQ. LENGTH	4	DRAWING NO. AC1195-01
7	CONNECTORS, (SIZE AND TYPE AS REQ.)	2	REV 0
8	SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16" (MIN)	4	DATE
9	GROUND WIRE, SOFT DRAWN COPPER, SOLID #6AWG	AS REQ	11/27/13
10	GROUND WIRE STAPLE	AS REQ	



53 OLD WILTON RD. • MILFORD, NH 03055 • 603-673-2040