

ITEM	DESCRIPTION	OTY	DESIGN PARAMETERS
1	ANGLE BRACKET, HENDRIX TYPE BA3-15 (15Kv)	1	15kV
2	INSULATOR, PIN TYPE, HENDRIX HPI-15VTP	3	LINE ANGLES: 7-60°
3	INSULATOR PIN, HENDRIX SSP-2	3	LINE ANGLES: 7 00
4	ANGLE CLAMP, HENDRIX CMA-1	1	TITLE
5	MESSENGER CABLE (TYPE AND SIZE AS NEEDED)	AS REQ	ANGLE CONSTRUCTION USING BA3-15
6	EYEBOLT, 3/4" X REQ LENGTH	1	
7	CONNECTOR, SIZE AND TYPE (AS REQ)	AS REQ	
8	HENDRIX AERIAL CABLE (VOLTAGE AND TYPE AS(NEEDED)	AS REQ	DRAWING NO. REV
9	MACHINE BOLT, 5/8" X REQUIRED LENGTH	2	AC1241-01 3
10	SQUARE WASHER, 2-1/4" X 2-1/4"X 3/16" (MIN)	2	DATE
11	GROUND WIRE, SOFT DRAWN COPPER, SOLID #6AWG	AS REQ	7/7/10
12	GUY HOOK	1	7/7/10
13	GROUND WIRE STAPLE	AS REQ	
			MONORIV
			<i>H</i> endrix*
			AERIAL CABLE SYSTEMS
			53 OLD WILTON RD. • MILFORD, NH 03055 • 603-673-2040