

	o in the first contains a first state of the first		
ITEM	DESCRIPTION	QTY	DESIGN PARAMETERS
1	VERTICAL TAP BRACKET, HENDRIX TYPE BV-35	1	15kV
2	INSULATOR, PIN TYPE, HENDRIX HPI-15VTP	3	
3	INSULATOR PIN, HENDRIX SSP-2	3	LINE ANGLES: 0-6°
4	INSULATOR, POLYMER DEAD-END TYPE	3	
5	HENDRIX AERIAL CABLE,(SIZE AND VOLTAGE RATING AS REQ.)	AS REQ	
6	MESSENGER, (SIZE AND TYPE AS REQUIRED)	AS REQ	TITLE
7	PRESHAPED CONDUCTOR GRIP, COATED	3	3-PHASE LATERAL TAP CONSTRUCTION
8	PRESHAPED MESSENGER GRIP	1	USING BV-35
9	MACHINE BOLT, 5/8" X REQ. LENGTH	4	001110 DV 00
10	SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16" (MIN)	3	DRAWING NO. REV
	SHACKLE CLEVIS, HENDRIX CATALOG NO. SC	3	AC1250-01 3
12	THIMBLE CLEVIS, HENDRIX CATALOG NO. TC	3	DATE
13	CONNECTORS, (SIZE AND TYPE AS REQ.)	AS REQ	12/20/10
14	EYE BOLT, 3/4" X REQ LENGTH	1	12/20/10
15	GUY HOOK	1	
	HEAVY DUTY THIMBLE CLEVIS, HENDRIX HDTC	1	Monariv
	MESSENGER BRACKET, HENDRIX TYPE BM-14	1	<i>H</i> endrix <sup>®</sup>
	HENDRIX LINEDUC, 8FT LONG	3	,
	GROUND WIRE, SOFT DRAWN COPPER, SOLID #6 AWG	AS REQ	
20	GROUND WIRE STAPLE	AS REQ	53 OLD WILTON RD. • MILFORD, NH 03055 • 603-673-2040