



ITEMS IN RED NOT SUPPLIED BY HENDRIX

ITEM	DESCRIPTION	QTY	DESIGN PARAMETERS
1	DEAD END BRACKET, HENDRIX TYPE BD-35	2	15kV
2	PIN TYPE INSULATOR, HENDRIX HPI-15VT	2	DOUBLE CIRCUIT
3	INSULATOR PIN, HENDRIX SSP-2	2	
4	INSULATOR, POLYMER DEAD END TYPE (15KV)	6	
5	HENDRIX AERIAL CABLE,(SIZE AND VOLTAGE RATING AS REQ.)	AS REQ	
6	MESSENGER, (SIZE AND TYPE AS REQUIRED)	AS REQ	
7	PRESHAPED CONDUCTOR GRIP, COATED	6	TITLE
8	PRESHAPED MESSENGER GRIP	2	DEAD-END ANGLE CONSTRUCTION
9	GUY HOOK, CONTINENTAL NO. GA-56X, OR EQUAL	2	
10	MACHINE BOLT, 5/8" X REQ. LENGTH	4	DRAWING NO. REV
11	HEAVY DUTY THIMBLE CLEVIS, HENDRIX CATALOG NO. HDTC	2	AC1256-01 2
12	THIMBLE CLEVIS, HENDRIX CATALOG NO. TC	6	DATE
13	SHACKLE CLEVIS, HENDRIX CATALOG NO. SC	6	10/04/06
14	SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16" (MIN)	4	
15	GROUND WIRE, SOFT DRAWN COPPER, SOLID, #6 AWG MIN.	AS REQ	
16	GROUND WIRE STAPLE, COPPER CLAD OR GALVANIZED	AS REQ	
17	CONNECTORS, (SIZE AND TYPE AS REQ.)	AS REQ	
18	EYE BOLT, 3/4" X REQ. LENGTH	2	



AERIAL CABLE SYSTEMS
53 OLD WILTON RD. • MILFORD, NH 03055 • 603-673-2040