

TEMO IN TED NOT OUT FIED BY HEADAIX			
ITEM	DESCRIPTION	QTY	DESIGN PARAMETERS
1	ANGLE BRACKET, HENDRIX TYPE BA4-15	1	15kV
2	INSULATOR, PIN TYPE, HENDRIX TYPE HPI-15VTP	3	LINE ANGLES: 7°-60°
3	INSULATOR PIN, HENDRIX TYPE SSP-2	3	
4	HENDRIX AERIAL CABLE, (SIZE AND VOLTAGE RATING AS REQ.)	AS REQ	TITLE
5	MESSENGER, (SIZE AND TYPE AS REQUIRED)	AS REQ	INSIDE ANGLE CONSTRUCTION USING BA4-15
6	EYEBOLT, 3/4"	1	
7	ANGLE CLAMP, HENDRIX CATALOG NO. CMA-2	1	
8	U-BOLT, HENDRIX TYPE UB	1	DRAWING NO. REV
9	MACHINE BOLT, 3/4" X REQ. LENGTH	4	AC1260-01 3
10	SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16" (MIN)	4	DATE
11	GROUND WIRE, SOFT DRAWIN COPPER, SOLID #6 AWG MIN.	AS REQ	1/7/11
12	CONNECTOR (SIZE AND TYPE AS REQ.)	AS REQ	1///11
13	GROUND WIRE STAPLE	AS REQ	
14	GUY STRAIN	1	LIODARIV*
			<i>H</i> endrix
\vdash			AERIAL CABLE SYSTEMS
		53 OLD WILTON RD. • MILFORD, NH 03055 • 603-673-2040	