			POSITIO OF GUV	
ITEM		DESCRIPTION	QTY	
1	NUMBER POLE-XX	POLE (TYPE, CLASS & LENGTH AS REQ.)	1	
2	SC-C5.21	15kV, 3-PHASE PRIMARY DOUBLE SUPPORT - SINGLE DEADEND ON CROSSARMS (WOOD)	1	
2.1	HDTC	THIMBLE CLEVIS - 40,000 LBS.	1	
2.2 2.3	MG-0000 DEINS15	PREFORMED GRIP, MESSENGER (SIZE & KIND AS REQ.) INSULATOR - DEAD END, 15kV	AS REQ 3	
2.3	TC	CLEVIS - THIMBLE	3	
2.5	CG-0000	PREFORMED GRIP, CONDUCTORS, COATED (SIZE & KIND AS REQ.)	3	
2.6 2.7	XARM-8FT BRACE-28IN	CROSSARM, 3-5/8 X 4-5/8 X 8'-0" BRACE, 28"	2	
2.8	EBLT3/4	BOLT, EYE, 3/4" X REQ. LENGTH	1	
2.9	DABLT5/8 LSCREW1/2X4	BOLT, DOUBLE ARMING, 5/8" X REQ. LENGTH SCREW, LAG, 1/2 X 4"	3	
2.10 2.11	CBLT3/8	SCREW, LAG, 1/2 X 4" BOLT, CARRIAGE, 3/8 X 4-1/2"	4	
2.12	SWSH5/8	WASHER, SQUARE, 5/8 X 2-1/4"	10	
2.13 2.14	SWSH3/4 LWSH5/8	WASHER, SQUARE, 3/4 X 2-1/4" WASHER, SPRINGLOCK, 5/8"	2	
2.14	LWSH3/4	WASHER, SPRINGLOCK, 3/4"	1]
2.16	ENUT5/8	NUT, EYE, 5/8"	3	RED ITEMS ARE NOT SUPPLIED BY HENDRIX
2.17	LNUT3/8 LNUT5/8	LOCKNUT, 3/8" LOCKNUT, 5/8"	4	
2.19	LNUT3/4	LOCKNUT, 3/4"	1	Hendrix ®
3	SC-P.03G	3-PHASE LIGHTNING ARRESTER GUIDE SPACER CABLE	1	
3.1 3.2	MOUNT-XX ARRESTER-XX	EQUIPMENT MOUNT (TYPE AS REQ.) LIGHTNING ARRESTER (TYPE & RATING AS REQ.)	AS REQ	
3.3	TAP WIRE	TAP WIRE, COVERED (SIZE AS REQ.), CUT TO SUIT	1	AERIAL CABLE SYSTEMS
3.4	CONNECTOR-XX	CONNECTOR (SIZE & TYPE AS REQUIRED)	AS REQ	53 OLD WILTON RD. MILFORD, NH 03055 (603) 673-2040
4	SC-H.01G CONNECTOR-XX	GROUNDING GUIDE SPACER CABLE CONNECTOR (SIZE & TYPE AS REQUIRED)	1	DESIGN PARAMETERS:
4.2	GNDWIRE-XX	GROUND WIRE, COPPER, #6 AWG (MIN) (LENGTH AS REQ.)	AS REO	KV CLASS: 15kV
4.3	STAPLE-XX	GROUND WIRE STAPLE (SIZE & TYPE AS REQUIRED)		LINE ANGLE: 0-6°
4.4 5	GNDASSY-XX SC-E.01G	GROUND ASSEMBLY (TYPE AS REQ., NOT SHOWN) GUYING GUIDE, SPACER CABLE	1	REVISION: 1
5.1	POLEEYE-XX	POLE-EYE PLATE (SIZE AND STRENGTH AS REQUIRED)	1	15KV 3-PHASE PRIMARY DRAWING NO
5.2	GUYSTRAIN-XX	GUY STRAIN (SIZE & TYPE AS REQUIRED)	AS REQ	
5.3 5.4	GUYSTRAND-XX ANCHORASSY-XX	GUY STRAND (SIZE AND TYPE AS REQUIRED) ANCHOR AND ANCHOR ROD (SIZE AND TYPE AS REQUIRED)	AS REQ	AC1264-01
5.4		ANUTOR AND ANUTOR RUD (SIZE AND I YPE AS REQUIRED)	1	