



ITEMS IN RED NOT SUPPLIED BY HENDRIX

ITEM	DESCRIPTION	QTY	DESIGN PARAMETERS
1	MESSENGER BRACKET, HENDRIX TYPE BM-14	1	15kV
2	TRANSFORMER TAP BRACKET, BT3-35	1	LINE ANGLES: 0-6°
3	INSULATOR, PIN TYPE, HENDRIX HPI-15VT	3	TITLE
4	INSULATOR PIN, HENDRIX SSP-2	3	TANGENT POLE TOP CONSTRUCTION WITH BT3-35
5	HENDRIX AERIAL CABLE,(SIZE AND VOLTAGE RATING AS REQ.)	AS REQ	DRAWING NO.      REV
6	MESSENGER, (SIZE AND TYPE AS REQUIRED)	AS REQ	<b>AC1276-01</b> <b>0</b>
7	CONNECTORS, (SIZE AND TYPE AS REQ.)	AS REQ	DATE
8	MACHINE BOLT, 3/4" X REQ. LENGTH	6	10/24/06
9	SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16" (MIN)	2	
10	GROUND WIRE, SOFT DRAWN COPPER, SOLID, 6 AWG MIN	AS REQ	
11	GROUND WIRE STAPLE	AS REQ	
12	POLE TOP EXTENSION BRACKET, HENDRIX TYPE XPT-75H	2	

