

## ITEMS IN RED NOT SUPPLIED BY HENDRIX

I I LIVI	S IN RED NOT SUPPLIED BY HENDRIA		
ITE№	DESCRIPTION	QTY	DESIGN PARAMETERS
1	ANGLE BRACKET, HENDRIX TYPE BA6-15	2	15kV
2	INSULATOR, PIN TYPE, HENDRIX HPI-15VTP	24	LINE ANGLES: 61°-90°
3	INSULATOR PIN, HENDRIX SSP-2	24	
4	HENDRIX AERIAL CABLE,(SIZE AND VOLTAGE RATING AS REQ.)	AS REQ	TITLE
5	MESSENGER, (SIZE AND TYPE AS REQUIRED)	AS REQ	STACKED - DOUBLE CIRCUIT CONSTRUCTIONS
6	PRESHAPED MESSENGER GRIP	8	USING BA6-15
7	GUY HOOK	8	DRAWING NO. REV
8	EYE BOLT, 3/4" X REQ. LENGTH	8	1-11-11-11-11-11-11-11-11-11-11-11-11-1
9	MACHINE BOLT, 5/8" X REQ. LENGTH	4	AC1283-01 1
10	THIMBLE CLEVIS, HENDRIX CATALOG NO. HDTC	8	
11	SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16" (MIN)	4	4/22/08
12	GROUND WIRE, SOFT DRAWN COPPER, SOLID, #6 AWG	AS REQ.	
13	GROUND WIRE STAPLES	AS REQ.	
14	CONNECTORS, (SIZE AND TYPE AS REQ.)	AS REQ	<i>Hendrix</i>
15	DOUBLE INSULATOR PLATE, HENDRIX 2IP	12	
			AERIAL CABLE SYSTEMS
			53 OLD WILTON RD. • MILFORD, NH 03055 • 603-673-2040