



ITEMS IN RED NOT SUPPLIED BY HENDRIX

PLEASE REFER TO INSTALLATION GUIDE FOR 3-PHASE TRANSFORMER TAP INSTRUCTIONS

ITEM	DESCRIPTION	QTY	DESIGN PARAMETERS
1	MESSENGER BRACKET, HENDRIX TYPE BM-14	1	15kV
2	STIRRUP, HENDRIX TYPE TS-1	1	LINE ANGLES: 0-6°
3	HENDRIX AERIAL CABLE (SIZE AND VOLTAGE AS REQ)	AS REQ	TITLE
4	MESSENGER (SIZE AND TYPE AS REQ)	AS REQ	3-PHASE TRANSFORMER TAP
5	TRANSFORMER, SINGLE PHASE TYPE SP (kVA AND VOLTAGE RATING AS REQ)	3	DRAWING NO.                      REV
6	ANTI-SWAY BRACKET, HENDRIX TYPE BAS-14F	1	<b>AC1284-01</b> <b>0</b>
7	SPACER, HENDRIX TYPE RTL-15	1	DATE
8	FUSED CUTOFF (TYPE AND VOLTAGE RATING AS REQ)	3	5/20/08
9	CONNECTOR (SIZE AND TYPE AS REQ)	AS REQ	
10	GROUND WIRE, SOFT DRAWN COPPER, SOLID #6 AWG	AS REQ	
11	GROUND WIRE STAPLE	AS REQ	
12	MACHINE BOLT, 5/8" X REQ LENGTH	4	
13	SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16"	4	
14	LAG SCREW, FETTER TYPE, 1/2" X 4"	1	
15	HENDRIX LINE DUC	AS REQ	
16	CLUSTER MOUNT	1	



53 OLD WILTON RD. • MILFORD, NH 03055 • 603-673-2040