



ITEM	DESCRIPTION	QTY	DESIGN PARAMETERS
1	ANGLE BRACKET, HENDRIX TYPE BA4-15	1	15KV
2	INSULATOR, HENDRIX TYPE HPI-15VTP	3	LINE ANGLES: 7-60°
3	INSULATOR PIN, HENDRIX SSP-2	3	TITLE
4	HENDRIX AERIAL CABLE,(SIZE AND VOLTAGE RATING AS REQ.)	AS REQ	TRANSFORMER TAP ON ANGLE CONSTRUCTION USING BA4-15
5	MESSENGER (SIZE AND TYPE AS REQUIRED)	AS REQ	DRAWING NO. REV
6	GUY HOOK, CONTENENTAL NO. GA-56X OR EQUAL	1	AC1286-01 0
7	ANGLE CLAMP, HENDRIX CATALOG NO. CMA-1	1	DATE
8	MACHINE BOLT, 5/8" X REQ. LENGTH	6	6/18/08
9	SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16" (MIN)	4	
10	GUY WIRE, SOLID SOFT DRAWN COPPER, #6 AWG	AS REQ	
11	GROUND WIRE STAPLE	AS REQ	
12	CONNECTORS, (SIZE AND TYPE AS REQ.)	AS REQ	
13	FUSED CUTOUT (SIZE AND VOLTAGE RATING AS REQ)	1	
14	TRANSFORMER, TYPE SP (KVA AND VOLTAGE RATING AS REQ)	1	
15	HENDRIX LINE DUC	AS REQ	
16	TAP CLAMP (SIZE AND TYPE AS REQ)	1	



53 OLD WILTON RD. • MILFORD, NH 03055 • 603-673-2040