

ITEMS IN	RED NOT	SUPPLIED	BY HENDRIX

ITEM	DESCRIPTION	QTY	DESIGN PARAMETERS		
1	ANGLE BRACKET HENDRIX BA6-15	2	15kV		
2 INSULATOR, PIN TYPE, HENDRIX HPI-15VTP		12	LINE ANGLES: 7°-60°		
3	INSULATOR PIN, HENDRIX SSP-2	12			
4	HENDRIX AERIAL CABLE,(SIZE AND VOLTAGE RATING AS REQ.)	AS REQ	TITLE		
5	MESSENGER, (SIZE AND TYPE AS REQUIRED)	AS REQ	4 CIRCUIT ANGLE CONSTRUCTION USING BA6-15		
6	POLE PLATE	4			
7	ANGLE CLAMP HENDRIX CMA-1	4			
8	MACHINE BOLT, 5/8" X REQ. LENGTH	8	DRAWING NO. REV		
9	EYE BOLT, 3/4" X REQ. LENGTH)	4	AC1287-01 0		
10	SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16" (MIN)	4	DATE		
11	GROUND WIRE, SOFT DRAWN COPPER, SOLID #6AWG MIN.	AS REQ	6/8/15		
12	GROUND WIRE STAPLE, COPPER CLAD OR GALVANIZED	AS REQ			
13	CONNECTOR, (SIZE AND TYPE AS REQ.)	9	<i>Hendrix</i>		
			AERIAL CABLE SYSTEMS		
$\vdash \vdash$			53 OLD WILTON RD. • MILFORD, NH 03055 • 603-673-2040		