

ITEMS IN RED NOT SUPPLIED BY HENDRIX

TEM	DESCRIPTION	QTY	DESIGN PARAMETERS 15kV
1	TRIANGULAR TAP BRACKET, HENDRIX TYPE BT-35	1	
2	TAP CLAMP (SIZE AND TYPE AS REQ)	3	
3	INSULATOR, PIN TYPE, HENDRIX HPI-15VTP	4	
4	INSULATOR PIN, HENDRIX SSP-2	4	
5	GUY HOOK	1	
6	INSULATOR, POLYMER DEAD-END TYPE (15KV)	3	
7	HENDRIX AERIAL CABLE (SIZE AND VOLTAGE RATING AS REQ.)	AS REQ	
8	MESSENGER (SIZE AND TYPE AS REQUIRED)	AS REC	TITLE
9	PRESHAPED CONDUCTOR GRIP, COATED	3	TRIANGULAR TAP CONSTRUCTION
10	PRESHAPED MESSENGER GRIP	1	USING BT-35 AND BM-14
11	MACHINE BOLT, 5/8" X REQ. LENGTH	4	OSING DI 33 AND DI 14
12	SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16" (MIN)	6	DRAWING NO. REV
13	SHACKLE CLEVIS, HENDRIX CATALOG NO. SC	3	AC1295-01 0
	THIMBLE CLEVIS, HENDRIX CATALOG NO. TC	3	DATE
15	CONNECTORS, (SIZE AND TYPE AS REQ.)	2	11/3/14
16	HEAVY DUTY THIMBLE CLEVIS, HENDRIX CATALOG NO. HDTC	1	
17	EYE BOLT, 3/4" X REQ LENGTH	1	
18	GROUND WIRE, SOFT DRAWN COPPER, SOLID #6 AWG	AS REC	
19	GROUND WIRE STAPLE	AS REC	71CIUIIX
20	HENDRIX LINEDUC, 8FT LONG	2	
21	MESSENGER BRACKET, HENDRIX TYPE BM-14	1	AERIAL CABLE SYSTEMS
		53 OLD WILTON RD. • MILFORD, NH 03055 • 603-673-2040	