



ITEMS IN RED NOT SUPPLIED BY HENDRIX

ITEM	DESCRIPTION	QTY	DESIGN PARAMETERS
1	MESSENGER BRACKET, HENDRIX TYPE BM-14	1	15kV
2	INSULATOR, PIN TYPE, HENDRIX HPI-15VTP	3	LINE ANGLES 0-6°
3	INSULATOR PIN, HENDRIX LSP-1	3	TITLE
4	CROSS-ARM, 8FT LONG	1	TANGENT CROSS-ARM CONSTRUCTION
5	MACHINE BOLT, 5/8" X REQ. LENGTH	2	USING BM-14
6	CONNECTOR, (SIZE AND TYPE AS REQ.)	1	DRAWING NO. REV
7	SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16" MIN	6	<b>AC1299-01</b> <b>0</b>
8	GROUND WIRE, SOFT DRAWN COPPER, SOLID, #6 AWG MIN	AS REQ	DATE
9	GROUND WIRE STAPLE	AS REQ	12/6/13
10	MESSENGER, (SIZE AND TYPE AS REQUIRED)	AS REQ	
11	HENDRIX AERIAL CABLE, (SIZE AND VOLTAGE RATING AS REQ.)	AS REQ	



AERIAL CABLE SYSTEMS  
53 OLD WILTON RD. • MILFORD, NH 03055 • 603-673-2040