



CABLES AND MESSINGERS
SLACK SPAN TO
SUBSTATION
STEEL STRUCTURE

ITEMS IN RED NOT SUPPLIED BY HENDRIX

ITEM	DESCRIPTION	QTY	DESIGN PARAMETERS
1	ANGLE BRACKET HENDRIX BA6-15	1	15kV
2	INSULATOR, PIN TYPE, HENDRIX HPI-15VTP	6	TITLE DOUBLE CIRCUIT SLACK SPAN CONSTRUCTION USING BA6-15
3	INSULATOR PIN, HENDRIX SSP-2	6	
4	HENDRIX AERIAL CABLE,(SIZE AND VOLTAGE RATING AS REQ.)	AS REQ	DRAWING NO. REV AC1302-01 0
5	MESSENGER, (SIZE AND TYPE AS REQUIRED)	AS REQ	
6	POLE EYE PLATE	2	DATE 3/4/14
7	MACHINE BOLT, 5/8" X REQ. LENGTH	2	 AERIAL CABLE SYSTEMS 53 OLD WILTON RD. • MILFORD, NH 03055 • 603-673-2040
8	EYE BOLT, 3/4" X REQ. LENGTH	4	
9	MACHINE BOLT, 3/4" X REQ. LENGTH	2	
10	SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16" (MIN)	4	
11	GROUND WIRE, SOFT DRAWN COPPER, SOLID #6AWG MIN.	AS REQ	
12	GROUND WIRE STAPLE, COPPER CLAD OR GALVANIZED	AS REQ	
13	CONNECTORS, (SIZE AND TYPE AS REQ.)	5	
14	FIBERGLASS GUY STRAIN X REQ. LENGTH	2	
15	PRESHAPED MESSENGER GRIP	4	