


ITEM	DESCRIPTION	QTY
1	HENDRIX AERIAL CABLE, (SIZE AND VOLTAGE AS REQ.)	AS REQ
2	MESSENGER, (SIZE AND TYPE AS REQ.)	AS REQ
3	INSULATOR, PIN TYPE, HENDRIX HPI-15VTP	6
4	INSULATOR PIN, HENDRIX TYPE LSP-1	6
5	PRESHAPED CONDUCTOR GRIP, COATED	3
6	PRESHAPED MESSENGER GRIP	1
7	INSULATOR, POLYMER DEAD-END HENDRIX DEINS15	6
8	HEAVY DUTY THIMBLE CLEVIS, HENDRIX HDTC	1
9	THIMBLE CLEVIS, CATALOG NO. TC	3
10	EYE NUT, STANDARD 3/4"	6
11	DOUBLE ARMING BOLT, 3/4" X REQ. LENGTH	6
12	GROUND WIRE, SOFT DRAWN COPPER, SOLID, #6 AWG MIN.	AS REQ
13	GROUND WIRE STAPLE	AS REQ
14	CONNECTOR, (SIZE AND TYPE AS REQ.)	3
15	FIBERGLASS STRAIN INSULATOR	1
16	POLE EYE PLATE	2
17	EYE BOLT, 3/4" X REQ. LENGTH	1
18	DEAD-END BARE WIRE CLAMP	3
19	SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16" MIN	20
20	MACHINE BOLT, 3/4" X REQ. LENGTH	6
21	PARALLEL GROOVE CLAMP	3
22	CROSS-ARM, 8FT LONG	4
23	LIGHTNING ARRESTER WITH MOUNTING BRACKET	3

DESIGN PARAMETERS	
15kV	
BUCK ARM DOUBLE CROSS-ARM CONSTRUCTION	
TITLE	
BUCK ARM DOUBLE DEAD-END TRANSITION SPACER CABLE TO BARE	
DRAWING NO.	REV
<b>AC1307-01</b>	<b>0</b>
DATE	
9/18/13	
 <b>AERIAL CABLE SYSTEMS</b> 53 OLD WILTON RD. • MILFORD, NH 03055 • 603-673-2040	