



ITEMS IN RED NOT SUPPLIED BY HENDRIX

ITEM	DESCRIPTION	QTY	DESIGN PARAMETERS
1	HENDRIX AERIAL CABLE (SIZE AND VOLTAGE RATING AS REQ.)	AS REQ	15kV DEAD-END
2	MESSENGER, (SIZE AND TYPE AS REQ.)	AS REQ	
3	PRESHAPED CONDUCTOR GRIP, COATED	6	
4	PRESHAPED MESSENGER GRIP	2	
5	INSULATOR, POLYMER DEAD-END TYPE, 15KV	6	
6	PUPI FIBERGLASS CROSS-ARM, 8FT LONG	2	
7	MACHINE BOLT, 5/8" X REQ. LENGTH	8	
8	SQUARE WASHER 2-1/4" X 2-1/4" X 3/16"	17	
9	HEAVY-DUTY THIMBLE CLEVIS, HENDRIX CATALOG NO. HDTC	2	
10	STANDARD-DUTY THIMBLE CLEVIS, HENDRIX CATALOG NO. TC	6	
11	GROUND WIRE, SOFT DRAWN COPPER, SOLID #6 AWG MIN.	AS REQ	TITLE
12	GROUND WIRE STAPLE	AS REQ	DOUBLE CIRCUIT CROSS-ARM DEAD-END CONSTRUCTION WITH UNDERGROUND RISER
13	CONNECTORS, (SIZE AND TYPE AS REQ.)	3	
14	HENDRIX COVERED TAP WIRE	AS REQ	DRAWING NO. REV
15	UNDERGROUND CABLE TERMINATOR	6	AC1312-01 1
16	UNDERGROUND RISER CABLE	AS REQ	DATE
17	UNDERGROUND RISER CONDUIT	2	8/23/16
18	EQUIPMENT MOUNT	2	
19	EYEBOLT, 3/4" X REQ LENGTH	2	
20	INSULATOR, PIN TYPE, HENDRIX HPI-15VTP	3	
21	INSULATOR PIN, HENDRIX TYPE SSP-2	3	



53 OLD WILTON RD. • MILFORD, NH 03055 • 603-673-2040