


ITEMS IN RED NOT SUPPLIED BY HENDRIX

ITEM	DESCRIPTION	QTY	DESIGN PARAMETERS
1	HENDRIX AERIAL CABLE, (SIZE AND VOLTAGE AS REQ.)	AS REQ	15kV DOUBLE CROSS-ARM CONSTRUCTION
2	MESSENGER, (SIZE AND TYPE AS REQ.)	AS REQ	
3	INSULATOR, PIN TYPE, HENDRIX HPI-15VTP	6	
4	INSULATOR PIN, LONG SHANK HENDRIX LSP-1	6	TITLE DEAD-END TRANSITION: TREE WIRE TO SPACER CABLE
5	PRESHAPED CONDUCTOR GRIP, COATED	3	
6	PRESHAPED MESSENGER GRIP	1	DRAWING NO. REV AC1318-01 0
7	INSULATOR, POLYMER DEAD-END HENDRIX DEINS15	6	
8	LIGHTNING ARRESTER WITH MOUNTING BRACKET	3	DATE 8/27/15
9	THIMBLE CLEVIS, CATALOG NO. TC	3	 AERIAL CABLE SYSTEMS 53 OLD WILTON RD. • MILFORD, NH 03055 • 603-673-2040
10	EYE NUT, STANDARD 5/8"	6	
11	DOUBLE ARMING BOLT, 5/8" X REQ. LENGTH	3	
12	GROUND WIRE, SOFT DRAWN COPPER, SOLID, #6 AWG MIN.	AS REQ	
13	GROUND WIRE STAPLE	AS REQ	
14	CONNECTORS, (SIZE AND TYPE AS REQ.)	3	
15	EYE BOLT, 3/4" X REQ. LENGTH	1	
16	HEAVY DUTY THIMBLE CLEVIS, HENDRIX HDTC	1	
17	UNIVERSAL GROOVE CLAMP, SIZE AND TYPE AS REQUIRED	3	
18	DEAD-END CLAMP FOR BARE WIRE, SIZE AND TYPE AS REQUIRED	3	
19	HENDRIX LINEDUC, 8FT LONG	1	