



ITEMS IN RED NOT SUPPLIED BY HENDRIX

| ITEM | DESCRIPTION | QTY | DESIGN PARAMETERS |
|------|---|--------|---|
| 1 | MESSENGER BRACKET, HENDRIX TYPE BM-14 | 1 | 15kV |
| 2 | STIRRUP, HENDRIX TYPE TS-1 | 1 | |
| 3 | SPACER, HENDRIX TYPE RTL-15 | 1 | TITLE |
| 4 | LAG SCREW, FETTER TYPE 1/2" X 4" | 1 | |
| 5 | LIGHTNING ARRESTOR | 2 | SINGLE PHASE OPEN WIRE TAPS FROM TANGENT CONSTRUCTION |
| 6 | ANTI-SWAY BRACKET, HENDRIX TYPE BAS-14F | 1 | |
| 7 | FUSED CUTOUT (TYPE AND VOLTAGE RATING AS REQ) | 2 | DRAWING NO. REV |
| 8 | INSULATOR, POLYMER DEADEND, 15kV, HENDRIX TYPE DEINS15 | 2 | |
| 9 | DEADEND CLAMP, (SIZE AND TYPE AS REQUIRED) | 2 | DATE |
| 10 | MACHINE BOLT, 5/8" X REQ. LENGTH | 4 | |
| 11 | SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16" (MIN) | 5 | 4/1/16 |
| 12 | GROUND WIRE, SOFT DRAWN COPPER, SOLID #6 AWG | AS REQ | |
| 13 | GROUND WIRE STAPLE | AS REQ | <p>Hendrix[®] AERIAL CABLE SYSTEMS 53 OLD WILTON RD. • MILFORD, NH 03055 • 603-673-2040</p> |
| 14 | HENDRIX AERIAL CABLE, (SIZE AND VOLTAGE RATING AS REQ.) | AS REQ | |
| 15 | CONNECTORS, (SIZE AND TYPE AS REQ.) | 2 | |
| 16 | EYE BOLT, 3/4" X REQ LENGTH | 1 | |
| 17 | TAP CLAMP (SIZE AND TYPE AS REQ.) | 2 | |
| 18 | HENDRIX LINE DUC, 8FT LONG | 2 | |
| 19 | MESSENGER, (SIZE AND TYPE AS REQ.) | AS REQ | |
| 20 | EQUIPMENT MOUNT | 2 | |
| 21 | EYENUT, 3/4" | 1 | |