



ITEMS IN RED NOT SUPPLIED BY HENDRIX

ITEM	DESCRIPTION	QTY	DESIGN PARAMETERS
1	ANGLE BRACKET, HENDRIX TYPE BA4-15	1	15KV
2	INSULATOR, HENDRIX TYPE HPI-15VTP	3	LINE ANGLES: 7-60°
3	INSULATOR PIN, HENDRIX SSP-2	3	TITLE
4	HENDRIX AERIAL CABLE,(SIZE AND VOLTAGE RATING AS REQ.)	AS REQ	TRANSFORMER TAP ON ANGLE CONSTRUCTION USING BA4-15 AND PSAC
5	MESSENGER (SIZE AND TYPE AS REQUIRED)	AS REQ	DRAWING NO. REV
6	POLE EYE PLATE	1	<b>AC1330-01</b> <b>0</b>
7	PERMANENT STRINGING ANGLE CLAMP, HENDRIX PSAC	1	DATE
8	MACHINE BOLT, 5/8" X REQ. LENGTH	7	9/21/16
9	SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16" (MIN)	6	
10	GROUND WIRE, SOLID SOFT DRAWN COPPER, #6 AWG	AS REQ	
11	GROUND WIRE STAPLE	AS REQ	
12	CONNECTORS, (SIZE AND TYPE AS REQ.)	AS REQ	
13	FUSED CUTOFF (SIZE AND VOLTAGE RATING AS REQ)	1	
14	TRANSFORMER, TYPE SP (KVA AND VOLTAGE RATING AS REQ)	1	
15	HENDRIX LINE DUC, 8FT LONG	1	
16	TAP CLAMP (SIZE AND TYPE AS REQ)	1	
17	COVERED TAP WIRE (SIZE AND TYPE AS REQ)	AS REQ	



53 OLD WILTON RD. • MILFORD, NH 03055 • 603-673-2040