



18	SQUARE WASHER, 2 1/4" X 2 1/4" X 3/16" (MIN)	No	20
17	SQUARE NUT, 5/8"	No	14
16	MACHINE BOLT, 3/4" X REQ. LENGTH	No	8
15	EYE PLATE, HENDRIX TYPE DEAD-END-TEE-01	No	4
14	EYE BOLT, 3/4" X REQ. LENGTH	No	6
13	GROUND WIRE STAPLE, COPPER CLAD OR GALVANIZED	No	AS REQ
12	GROUND WIRE, SOFT DRAWN COPPER, SOLID #6 AWG (MIN)	No	AS REQ
11	CONNECTOR, SIZE AND TYPE AS REQ.	No	AS REQ
10	FIBER GLASS STRAIN INSULATOR	No	2
9	INSULATOR, HENDRIX HPI-15VTP	Yes	6
8	PRESHAPED CONDUCTOR GRIP, COATED	Yes	6
7	THIMBLE CLEVIS, HENDRIX TYPE HDTC	Yes	2
6	THIMBLE CLEVIS, HENDRIX TYPE IC	Yes	6
5	PRESHAPED MESSENGER GRIP	Yes	2
4	INSULATOR, DEAD END TYPE DEINS15	Yes	6
3	INSULATOR PIN, HENDRIX TYPE ISP-1	Yes	6
2	HENDRIX ARIAL CABLE, SIZE AND VOLTAGE RATING AS REQ.	Yes	AS REQ
1	MESSENGER (SIZE AND TYPE AS REQ.)	Yes	AS REQ
<b>ITEM</b>	<b>DESCRIPTION</b>	<b>HENDRIX SUPPLIED</b>	<b>QTY</b>

DESIGN PARAMETERS

15Kv  
 LINE ANGLE: N/A

TITLE  
**BUCK ARM DOUBLE DEAD-END TRANSITION  
 SPACER CABLE TO SPACER CABLE**

DRAWING NO. **AC1331-01** REV **0**

DATE **01/09/2017** Drawn By **M. Sokolskiy**

**Hendrix**  
 AERIAL CABLE SYSTEMS

53 OLD WILTON RD. • MILFORD, NH 03055 • 603-673-2040

