



ITEMS IN RED NOT SUPPLIED BY HENDRIX

ITEM	DESCRIPTION	QTY	DESIGN PARAMETERS
1	MESSENGER BRACKET, HENDRIX TYPE BM-14	1	15kV
2	ANGLE BRACKET, HENDRIX TYPE BA3-35	1	LINE ANGLES: 0-6°
3	INSULATOR, PIN TYPE, HENDRIX HPI-15VTP	3	ELEVATION CHANGE: 20°
4	INSULATOR PIN, HENDRIX SSP-2	3	TITLE
5	HENDRIX AERIAL CABLE,(SIZE AND VOLTAGE RATING AS REQ.)	AS REQ	STEEP GRADE CONSTRUCTION USING BA3-35
6	MESSENGER, (SIZE AND TYPE AS REQUIRED)	AS REQ	DRAWING NO. REV
7	MACHINE BOLT, 5/8"OR 3/4"X REQ. LENGTH	4	AC2011-01 0 SPACER CABLE SYSTEMS
8	SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16" (MIN)	4	DATE
9	CONNECTORS, (SIZE AND TYPE AS REQ.)	AS REQ	1/8/10
10	GROUND WIRE, SOFT DRAWN COPPER, SOLID #6AWG	AS REQ	
11	GROUND WIRE STAPLE	AS REQ	



MARMON UTILITY LLC • 53 OLD WILTON RD. • MILFORD, NH 03055