

## ITEMS IN RED NOT SUPPLIED BY HENDRIX

ITEM	DESCRIPTION	QTY	DESIGN PARAMETERS
1	DEAD END BRACKET, HENDRIX TYPE BD-35	1	
2	HORIZONTAL TAP BRACKET, HENDRIX TYPE BA-6-15-25C	1	15kV
3	INSULATOR, PIN TYPE, HENDRIX HPI-15VTP	3	LINE ANGLES: 0-6°
4	INSULATOR PIN, HENDRIX SSP-2	3	
5	INSULATOR, POLYMER DEAD-END TYPE, 15KV	3	
6	HENDRIX AERIAL CABLE,(SIZE AND VOLTAGE RATING AS REQ.)	AS REQ	
7	MESSENGER, (SIZE AND TYPE AS REQUIRED)	AS REQ	TITLE
8	PRESHAPED CONDUCTOR GRIP, COATED	3	3-PHASE LATERAL TAP CONSTRUCTION
9	PRESHAPED MESSENGER GRIP	3	USING BD-35 AND BA6-15-25C
10	MACHINE BOLT, 5/8" OR 3/4" X REQ. LENGTH	4	031110 BB 33 7111B B710 13 23C
11	SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16" (MIN)	4	DRAWING NO. REV
12	SHACKLE CLEVIS, HENDRIX CATALOG NO. SC	3	AC2015-01 0 SPACER CABLE SYSTEMS
13	THIMBLE CLEVIS, HENDRIX CATALOG NO. TC	3	DATE
14	CONNECTORS, (SIZE AND TYPE AS REQ.)	AS REQ	2-18-10
	EYE BOLT, 3/4" X REQ. LENGTH	2	2 10 10
16	GROUND WIRE, SOFT DRAWN COPPER, SOLID #6 AWG	AS REQ	
17	GROUND WIRE STAPLE	AS REQ	<b>HENDRIX</b>
18	EYENUT, 3/4"	1	
19	HEAVY DUTY THIMBLE CLEVIS, HENDRIX CATALOG	3	
20	GUY HOOK	1	
	TELEPHONE, CO2 C72 2040, FAV. C02 C72 4407, FMAYL, OVER	MARMON UTILITY LLC• 53 OLD WILTON RD. • MILFORD, NH 03055	