



ITEMS IN RED NOT SUPPLIED BY HENDRIX

ITEM	DESCRIPTION	QTY	DESIGN PARAMETERS
1	EYE BOLT, 3/4"	4	15kV
2	EYENUT, 3/4"	4	LINE ANGLES: 0-6°
3	INSULATOR, PIN TYPE, HENDRIX HPI-15VTP	3	TITLE
4	INSULATOR PIN, HENDRIX SSP-2	3	TREE WIRE VERTICAL DOUBLE DEAD-END
5	INSULATOR, POLYMER DEAD-END TYPE, 15KV	6	DRAWING NO. AC2018-01
6	PARALLEL GROOVE CLAMP (SIZE AND TYPE AS REQ)	6	REV 0
7	LINE POST INSULATOR BRACKET	3	DATE 7/20/2010
8	HENDRIX AERIAL CABLE,(SIZE AND VOLTAGE RATING AS REQ)	AS REQ	SPACER CABLE SYSTEMS
9	MESSENGER, (SIZE AND TYPE AS REQUIRED)	AS REQ	
10	PRESHAPED MESSENGER GRIP	2	
11	MACHINE BOLT, 5/8" X REQ. LENGTH	6	
12	SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16" (MIN)	6	
13	SHACKLE CLEVIS, HENDRIX CATALOG NO. SC	6	
14	HEAVY DUTY THIMBLE CLEVIS, HENDRIX CATALOG NO. HDTC	2	
15	CONNECTORS, (SIZE AND TYPE AS REQ)	AS REQ	
16	DEAD-END CLAMP FOR BARE WIRE	6	



MARMON UTILITY LLC • 53 OLD WILTON RD. • MILFORD, NH 03055