



ITEMS IN RED NOT SUPPLIED BY HENDRIX

ITEM	DESCRIPTION	QTY	DESIGN PARAMETERS
1	MESSENGER BRACKET, HENDRIX TYPE BM-14	1	15kV
2	VERTICAL TAP BRACKET, HENDRIX TYPE BT3-35	1	LINE ANGLES: 0-6°
3	INSULATOR, PIN TYPE, HENDRIX HPI-15VTP	3	TITLE
4	INSULATOR PIN, HENDRIX SSP-2	3	3-PHASE TRANSFORMER TAP CONSTRUCTION
5	HENDRIX AERIAL CABLE, (SIZE AND VOLTAGE RATING AS REQ.)	AS REQ	USING BT3-35
6	MESSENGER, (SIZE AND TYPE AS REQUIRED)	AS REQ	DRAWING NO. REV
7	TRANSFORMER, SINGLE PHASE TYPE SP (KVA AND VOLTAGE RATING AS REQ)	3	AC2023-01 0 SPACER CABLE SYSTEMS
8	FUSED CUTOUT (TYPE AND VOLTAGE RATING AS REQ)	AS REQ	DATE
9	CONNECTOR (SIZE AND TYPE AS REQ)	AS REQ	11/30/10
10	MACHINE BOLT, 5/8" X REQ. LENGTH	6	
11	SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16" (MIN)	6	
12	LINE DUC	AS REQ	
13	CLUSTER MOUNT	1	
14	TAP CLAMP	3	
15	HENDRIX COVERED TAP WIRE (SIZE AND TYPE AS REQ)	AS REQ	
16	GROUND WIRE STAPLE	AS REQ	
17	GROUND WIRE, SOFT DRAWN COPPER, SOLID #6 AWG	AS REQ	



MARMON UTILITY LLC • 53 OLD WILTON RD. • MILFORD, NH 03055