



ITEM	DESCRIPTION	QTY	DESIGN PARAMETERS
1	DEAD END BRACKET, HENDRIX TYPE BD-35	2	15KV DEAD-END
2	HENDRIX AERIAL CABLE (SIZE AND VOLTAGE RATING AS REQ.)	AS REQ.	
3	MESSENGER, (SIZE AND TYPE AS REQ.)	AS REQ.	
4	FRESHAPED CONDUCTOR GRIP, COATED	6	
5	FRESHAPED MESSENGER GRIP	2	
6	INSULATOR, PIN TYPE, HENDRIX TYPE HPI-15VTP	3	TITLE
7	SHACKLE CLEVIS, HENDRIX CATALOG NO. SC	6	
8	POLE EYE PLATE	2	
9	MACHINE BOLT, 5/8" X REQ. LENGTH	8	
10	SQUARE WASHER 2-1/4" X 2-1/4" X 3/16" (MIN)	12	
11	HEAVY-DUTY THIMBLE CLEVIS, HENDRIX CATALOG NO. HDTC	2	
12	STANDARD-DUTY THIMBLE CLEVIS, HENDRIX CATALOG NO. TC	6	
13	GROUND WIRE, SOFT DRAWN COPPER, SOLID #6 AWG MIN.	AS REQ.	
14	GROUND WIRE STAPLE	AS REQ.	
15	CORNER JOBS, (SIZE AND TYPE AS REQ.)	AS REQ.	
16	FUSED CUTOUPS	6	STACKED DEAD-END CONSTRUCTION USING BD-35 WITH UNDERGROUND RISERS
17	OUTDOOR TERMINATION KIT, SIZE AS REQ.	6	
18	UNDERGROUND RISER CABLE	AS REQ.	
19	CONDUIT	AS REQ.	
20	SURGE ARRESTER, SIZE AS REQ.	6	
21	COVERED TAP WIRE	AS REQ.	
22	HUGHES BROS. CF910-4 EQUIPMENT MOUNTING BRACKET	AS REQ.	
23	EYEBOLT, 3/4" X REQ. LENGTH	2	
24	GUY STRAIN, FIBERGLASS	2	
25	MACHINE BOLT, 3/4" X REQ. LENGTH	4	
26	INSULATOR PIN, HENDRIX TYPE SSP-2	2	DRAWING NO. AC2027-01 REV 0 SPACER CABLE SYSTEMS
27	INSULATOR BRACKET, HENDRIX TYPE BP-1	2	
28	INSULATOR PIN, FEEDER TYPE	1	
29	2-HOLE COMPRESSION LUG, SIZE AS REQ.	3	
30	DEAD-END INSULATOR, POLYMER, 15KV	6	
			DATE 5/29/13

