

ITEMS IN RED NOT SUPPLIED BY HENDRIX

| | D.F.O.COLUMN TO ALL | OTV | DESIGN PARAMETERS |
|------|--|--------|---|
| ITEM | | QTY | 4 |
| 1 | MESSENGER BRACKET, HENDRIX TYPE BM-28 | 1 |] 15kV |
| 2 | TRANSFORMER TAP BRACKET, HENDRIX TYPE BT3-35-18 | 1 | LINE ANGLES: 0-6° |
| 3 | INSULATOR, PIN TYPE, HENDRIX HPI-15VTP | 3 | LINE ANGLES: 0 0 |
| 4 | INSULATOR PIN, HENDRIX SSP-2 | 3 | TITLE |
| 5 | HENDRIX AERIAL CABLE,(SIZE AND VOLTAGE RATING AS REQ.) | AS REQ | STEEP GRADE CONSTRUCTION |
| 6 | MESSENGER, (SIZE AND TYPE AS REQUIRED) | AS REQ | USING BT3-35-18 FOR GO95 |
| 7 | MACHINE BOLT, 3/4" X REQ. LENGTH | 4 | 001110 210 00 10 10 10 10 10 10 10 10 10 10 10 1 |
| 8 | SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16" (MIN) | 4 | DRAWING NO. REV |
| 9 | GROUND WIRE, SOFT DRAWN COPPER, SOLID #6 AWG | AS REQ | AC2031-01 0 SPACER CABLE SYSTEMS |
| 10 | GROUND WIRE STAPLE | | DATE |
| 11 | CONNECTORS, (SIZE AND TYPE AS REQ.) | AS REQ | 4/12/11 |
| | | | |
| | | | VI D U V |
| | | | HENDRIX |
| | | | |
| | | | |
| | | | MARMON UTILITY LLC• 53 OLD WILTON RD. • MILFORD, NH 03055 |