

ITEM	DESCRIPTION	QTY	DESIGN PARAMETERS
1	HEAVY DUTY THIMBLE CLEVIS, HENDRIX TYPE HDTC	2	15kV
2	VERTICAL TAP BRACKET, HENDRIX TYPE BV-35-18	1	LINE ANGLES: 61-90°
3	INSULATOR, PIN TYPE, HENDRIX HPI-15VTP	6	LINE ANGLES: 01 30
4	INSULATOR PIN, HENDRIX SSP-2	6	TITLE
5	HENDRIX AERIAL CABLE, (SIZE AND VOLTAGE RATING AS REQ.)	AS REQ	ANGLE CONSTRUCTION USING
6	MESSENGER, (SIZE AND TYPE AS REQUIRED)	AS REQ	BV-35-18 FOR GO95
7	MACHINE BOLT, 3/4" X REQ. LENGTH	2	DV 33 10 1 0 K G033
8	SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16" (MIN)	4	DRAWING NO. REV
9	GROUND WIRE, SOFT DRAWN COPPER, SOLID #6 AWG	AS REQ	AC2034-01 1 SPACER CABLE SYSTEMS
10	GROUND WIRE STAPLE		DATE
11	CONNECTORS, (SIZE AND TYPE AS REQ.)	AS REQ	9/10/13
12	EYEBOLT, 3/4" X REQ LENGTH	1	5/10/13
13	PRE-SHAPED MESSENGER GRIP	2	WE WANTED TO
14	DOUBLE INSULATOR PLATE, HENDRIX TYPE 2IP	3	HENDRIX
			TI LII LII LII I
			MARMON UTILITY LLC• 53 OLD WILTON RD. • MILFORD, NH 03055
		, , , , , , , , , , , , , , , , , , , ,	