


ITEMS IN RED NOT SUPPLIED BY HENDRIX

ITEM	DESCRIPTION	QTY	DESIGN PARAMETERS
1	HENDRIX AERIAL CABLE, (SIZE AND VOLTAGE AS REQ.)	AS REQ	15kV DOUBLE CROSS-ARM CONSTRUCTION
2	MESSENGER, (SIZE AND TYPE AS REQ.)	AS REQ	
3	GOLB SWITCH WITH MOUNTING BRACKET	1	
4	LIGHTNING ARRESTER WITH MOUNTING BRACKET	3	TITLE DEAD-END TRANSITION: SPACER CABLE TO BARE WIRE WITH GOLB SWITCH
5	PRESHAPED CONDUCTOR GRIP, COATED	3	
6	PRESHAPED MESSENGER GRIP	1	DRAWING NO. REV AC2035-01 0 SPACER CABLE SYSTEMS
7	INSULATOR, POLYMER DEAD-END HENDRIX DEINS15	6	
8	HEAVY DUTY THIMBLE CLEVIS, HENDRIX HDTC	1	DATE 4/28/11
9	THIMBLE CLEVIS, CATALOG NO. TC	3	 <p>HENDRIX</p> <p>MARMON UTILITY LLC • 53 OLD WILTON RD. • MILFORD, NH 03055</p>
10	EYE NUT, STANDARD 3/4"	6	
11	DOUBLE ARMING BOLT, 3/4" X REQ. LENGTH	3	
12	GROUND WIRE, SOFT DRAWN COPPER, SOLID, #6 AWG MIN.	AS REQ	
13	GROUND WIRE STAPLE	AS REQ	
14	CONNECTORS, (SIZE AND TYPE AS REQ.)	AS REQ	
15	FIBERGLASS STRAIN INSULATOR, CONTINENTAL NO. GCC21-36R	1	
16	POLE EYE PLATE	1	
17	EYE BOLT, 3/4" X REQ. LENGTH	1	
18	DEAD-END BARE WIRE CLAMP	3	
19	SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16" MIN	4	