

TILI	DESCRIPTION	QII	DESIGN PARAMETERS
1	MESSENGER BRACKET, HENDRIX TYPE BM-14	1	15kV
2	HORIZONTAL BRACKET, HENDRIX TYPE BA6-15-25C	2	
3	INSULATOR, PIN TYPE, HENDRIX HPI-15VTP	9	
4	INSULATOR PIN, HENDRIX SSP-2	9	
5	HENDRIX COVERED TAP WIRE	AS REQ	TITLE
6	DOUBLE INSULATOR PLATE, HENDRIX TYPE 2IP	3	STACKED SPACER CABLE USING BA6-15-25C
7	HENDRIX AERIAL CABLE, (SIZE AND VOLTAGE RATING AS REQ.)	AS REQ	TAP FROM BARE WIRE
8	MESSENGER, (SIZE AND TYPE AS REQUIRED)	AS REQ	
9	PRESHAPED MESSENGER GRIP	2	DRAWING NO. REV
10	MACHINE BOLT, 5/8" X REQ. LENGTH	2	AC2046-01 0 SPACER CABLE SYSTEMS
11	MACHINE BOLT, 3/4" X REQ. LENGTH	4	DATE
12	SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16" (MIN)	8	11/18/11
13	HEAVY DUTY THIMBLE CLEVIS, HENDRIX CATALOG NO. HDTC	2	11/10/11
14	GROUND WIRE, SOFT DRAWN, COPPER SOLID #6 AWG	AS REQ	
15	GROUND WIRE STAPLE	AS REQ	🛛 🔀 HENDRIX
16	CONNECTORS, (SIZE AND TYPE AS REQ.)	9	
17	EYE BOLT, 3/4" X REQ LENGTH	2	
18	HENDRIX LINE DUC, 8FT LONG	2	MARMON UTILITY LLC• 53 OLD WILTON RD. • MILFORD, NH 03055
			MARMON UTILITY LECC 33 OLD WILTON RD. * MILFORD, NH 03055

TELEPHONE: 603-673-2040 FAX: 603-673-1497 EMAIL: OVERHEAD@HENDRIX-WC.COM WEBSITE: HTTP://WWW.HENDRIX-WC.COM A MARMON WIRE & CABLE/BERKSHIRE HATHAWAY COMPANY