

TEM	DESCRIPTION	QTY	DESIGN PARAMETERS
1	MESSENGER BRACKET, HENDRIX TYPE BM-14	1	15kV
2	SPACER, HENDRIX TYPE RTL-15	1	LINE ANGLES: 0-6°
3	ANTI-SWAY BRACKET, HENDRIX TYPE BAS-14F	1	
4	STIRRUP, HENDRIX TYPE TS-1	1	
5	HENDRIX AERIAL CABLE, (SIZE AND VOLTAGE RATING AS REQ.)	AS REQ	TITLE
6	MESSENGER, (SIZE AND TYPE AS REQUIRED)	AS REQ	3-PHASE BARE WIRE TAP AT TANGENT LOCATION
7	HENDRIX LINEDUC, 8FT LONG	2	
8	LIGHTINING ARRESTER WITH MOUNTING BRACKET	3	
9	GUY STRAIN INSULATOR, FIBERGLASS	1	DRAWING NO. REV
10	TAP CLAMP	3	AC2059-01 1
11	INSULATOR, POLYMER DEAD-END HENDRIX TYPE DEINS15	3	DATE
12	GROUND WIRE, SOFT DRAWN, SOLID #6 AWG MIN.	AS REQ	3/1/16
13	GROUND WIRE STAPLE	AS REQ	5/1/10
14	DOUBLE ARMING BOLT, 5/8" X REQ. LENGTH	3	
15	CONNECTORS, (SIZE AND TYPE AS REQ.)	4	
			<b>Hendrix</b>
			AERIAL CABLE SYSTEMS

