



ITEMS IN RED NOT SUPPLIED BY HENDRIX

| ITEM | DESCRIPTION | QTY | DESIGN PARAMETERS |
|------|---|--------|--|
| 1 | MESSENGER BRACKET, HENDRIX TYPE BM-24 | 1 | 15kV |
| 2 | TRANSFORMER TAP BRACKET, HENDRIX TYPE BT3-35-18 | 1 | LINE ANGLES: 0-6° |
| 3 | INSULATOR, PIN TYPE, HENDRIX HPI-15VTP | 3 | TITLE |
| 4 | INSULATOR PIN, HENDRIX SSP-2 | 3 | TANGENT CONSTRUCTION USING BT3-35-18 AND BM-24 |
| 5 | HENDRIX AERIAL CABLE, (SIZE AND VOLTAGE RATING AS REQ.) | AS REQ | DRAWING NO. AC2079-01 |
| 6 | MESSENGER, (SIZE AND TYPE AS REQUIRED) | AS REQ | REV 0 |
| 7 | MACHINE BOLT, 3/4" X REQ. LENGTH | 4 | DATE 9/11/13 |
| 8 | SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16" (MIN) | 4 | |
| 9 | GROUND WIRE, SOFT DRAWN COPPER, SOLID #6 AWG | AS REQ | |
| 10 | GROUND WIRE STAPLE | AS REQ | |
| 11 | CONNECTORS, (SIZE AND TYPE AS REQ.) | AS REQ | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |



MARMON UTILITY LLC • 53 OLD WILTON RD. • MILFORD, NH 03055