



NOTE:  
1. FUTURE CONSTRUCTION QUANTITIES NOT ADDED TO BOM.

ITEM	DESCRIPTION	QTY	DESIGN PARAMETERS
1	HENDRIX AERIAL CABLE, (SIZE AND VOLTAGE AS REQ.)	AS REQ	15KV
2	MESSENGER, (SIZE AND TYPE AS REQ.)	AS REQ	BUCK ARM TRIPLE CROSS-ARM CONSTRUCTION WITH ONE CROSS-ARM FOR FUTURE CONSTRUCTION
3	INSULATOR, PIN TYPE, HENDRIX HPI-15VTP	4	
4	INSULATOR PIN, HENDRIX TYPE LSP-1	4	
5	PRESHAPED CONDUCTOR GRIP, COATED	9	
6	PRESHAPED MESSENGER GRIP	3	
7	INSULATOR, POLYMER DEAD-END HENDRIX DEINS15	15	
8	HEAVY DUTY THIMBLE CLEVIS, HENDRIX HDTC	3	
9	THIMBLE CLEVIS, CATALOG NO. TC	9	
10	EYE NUT, STANDARD 3/4"	15	TITLE
11	DOUBLE ARMING BOLT, 3/4" X REQ. LENGTH	12	BUCK ARM TRIPLE DEAD-END TRANSITION SPACER CABLE TO BARE
12	GROUND WIRE, SOFT DRAWN COPPER, SOLID, #6 AWG MIN.	AS REQ	DRAWING NO. REV
13	GROUND WIRE STAPLE	AS REQ	AC2080-01 0 SPACER CABLE SYSTEMS
14	CONNECTOR, (SIZE AND TYPE AS REQ.)	5	DATE
15	POLE EYE PLATE	3	9/26/13
16	EYE BOLT, 3/4" X REQ. LENGTH	3	SHEET 6 OF 6
17	DEAD-END BARE WIRE CLAMP	6	
18	SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16" MIN	14	
19	MACHINE BOLT, 3/4" X REQ. LENGTH	4	
20	PARALLEL GROOVE CLAMP	6	
21	CROSS-ARM, 8FT LONG	6	
22	LIGHTNING ARRESTER WITH MOUNTING BRACKET	6	

