


ITEMS IN RED NOT SUPPLIED BY HENDRIX

| ITEM | DESCRIPTION | QTY | DESIGN PARAMETERS |
|------|--|--------|--|
| 1 | DEAD-END BRACKET, HENDRIX TYPE BD-35 | 2 | 15kV 90DEG CIRCUIT CORNER |
| 2 | INSULATOR, PIN TYPE, HENDRIX HPI-15VTP | 3 | |
| 3 | INSULATOR PIN, HENDRIX SSP-2 | 3 | TITLE DEAD-END CORNER CONSTRUCTION USING BD-35 WITH FUSED 3-PHASE LATERAL AND 1-PHASE TAP |
| 4 | INSULATOR, POLYMER DEAD-END, HENDRIX TYPE DEINS15 | 7 | |
| 5 | HENDRIX AERIAL CABLE (SIZE AND TYPE AS REQ) | AS REQ | DRAWING NO. REV AC2103-01 0 SPACER CABLE SYSTEMS |
| 6 | MESSENGER (SIZE AND TYPE AS REQ) | AS REQ | |
| 7 | PRESHAPED CONDUCTOR GRIP, COATED | 6 | DATE 7/10/15 |
| 8 | PRESHAPED MESSENGER GRIP | 2 | |
| 9 | POLE EYE PLATE | 2 |  |
| 10 | MACHINE BOLT, 5/8" X REQ. LENGTH | 8 | |
| 11 | INSULATOR PLATE, HENDRIX BP-1 | 2 | |
| 12 | CONNECTOR (SIZE AND TYPE AS REQ) | 7 | |
| 13 | GROUND WIRE, SOFT DRAWN COPPER, SOLID #6 | AS REQ | |
| 14 | GROUND WIRE STAPLE | AS REQ | |
| 15 | SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16" (MIN) | 13 | |
| 16 | HEAVY DUTY THIMBLE CLEVIS, HENDRIX TYPE HDTC | 2 | |
| 17 | 3-PHASE FUSED CUTOUT ASSEMBLY (TYPE AND VOLTAGE RATING AS REQ) | 1 | |
| 18 | SINGLE PHASE CUTOUT AND LIGHTNING ARRESTOR ASSEMBLY | 1 | |
| 19 | DEAD-END CLAMP FOR BARE WIRE | 1 | |
| 20 | UNIVERSAL GROOVE CLAMP | 1 | |
| 21 | MACHINE BOLT, 3/4" X REQ. LENGTH | 4 | |
| 22 | EYEBOLT, 3/4" X REQ. LENGTH | 2 | |
| 23 | EYENUT, 3/4" | 1 | |
| 24 | SHACKLE CLEVIS, HENDRIX TYPE SC | 7 | |
| 25 | THIMBLE CLEVIS, HENDRIX TYPE TC | 6 | |