


ITEM	DESCRIPTION	QTY	DESIGN PARAMETERS
1	MACHINE BOLT, 3/4" X REQUIRED LENGTH	2	15kV DEAD-END
2	HENDRIX AERIAL CABLE, (SIZE AND TYPE AS REQ.)	AS REQ.	
3	MESSENGER, (SIZE AND TYPE AS REQ.)	AS REQ.	
4	PRESHAPED MESSENGER GRIP	1	
5	PRESHAPED CONDUCTOR GRIP, COATED	3	TITLE
6	INSULATOR, POLYMER DEAD-END TYPE, 15kV	3	
7	SHACKLE CLEVIS, HENDRIX CATALOG NO. SC	3	LREC DEAD END POLE
8	DEAD END TEE	2	DRAWING NO.          REV
9	HPIS-VTP WITH SSP-2	2	
10	THIMBLE CLEVIS, HENDRIX CATALOG NO. TC	3	DATE
11	MACHINE BOLT, 5/8" X REQUIRED LENGTH	2	11/28/16
12	SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16" (MIN)	2	SPACER CABLE SYSTEMS
13	GROUND WIRE, SOFT DRAWN COPPER, SOLID #6 AWG MIN.	AS REQ.	
14	GROUND WIRE STAPLE	AS REQ.	 AERIAL CABLE SYSTEMS 53 OLD WILTON RD. • MILFORD, NH 03055 • 603-673-2040
15	CONNECTORS, (SIZE AND TYPE AS REQ.)	AS REQ.	
16	DEAD END BRACKET, HENDRIX BD-35	1	