


ITEMS IN RED NOT SUPPLIED BY HENDRIX

ITEM	DESCRIPTION	QTY	DESIGN PARAMETERS
1	MESSENGER BRACKET, HENDRIX TYPE BM-14	1	35kV
2	INSULATOR, PIN TYPE, HENDRIX HPI-35VTP	2	LINE ANGLES: 61°-90°
3	INSULATOR PIN, HENDRIX SSP-2	2	TITLE
4	HENDRIX AERIAL CABLE, (SIZE AND VOLTAGE RATING AS REQ.)	AS REQ.	SINGLE PHASE ANGLE CONSTRUCTION
5	MESSENGER, (SIZE AND TYPE AS REQUIRED)	AS REQ.	DRAWING NO. REV
6	PRESHAPED MESSENGER GRIP	2	AC1168-03 3
7	GUY HOOK	2	DATE
8	THIMBLE CLEVIS, HENDRIX HDTC	2	8/28/07
9	EYE BOLT, 3/4" X REQ LENGTH	2	 AERIAL CABLE SYSTEMS 53 OLD WILTON RD. • MILFORD, NH 03055 • 603-673-2040
10	MACHINE BOLT, 5/8" X REQ. LENGTH	2	
11	SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16" (MIN)	3	
12	GROUND WIRE, SOFT DRAWN SOLID, #6 AWG MIN	AS REQ.	
13	GROUND WIRE STAPLE	AS REQ.	
14	CONNECTORS, (SIZE AND TYPE AS REQ.)	AS REQ.	
15	DOUBLE INSULATOR PLATE, HENDRIX 2IP	1	