


ITEMS IN RED NOT SUPPLIED BY HENDRIX

| ITEM | DESCRIPTION | QTY | DESIGN PARAMETERS |
|------|---|--------|---|
| 1 | THIMBLE CLEVIS, HEAVY DUTY, HENDRIX TYPE HDTC | 2 | 25kV TANGENT CONSTRUCTION |
| 2 | EYE BOLT, 3/4" X REQ LENGTH | 2 | |
| 3 | PRESHAPED MESSENGER GRIP | 2 | |
| 4 | MESSENGER, (SIZE AND TYPE AS REQUIRED) | AS REQ | |
| 5 | PRESHAPED CONDUCTOR GRIP, COATED | 2 | |
| 6 | HENDRIX AERIAL CABLE, (SIZE AND VOLTAGE RATING AS REQ.) | AS REQ | |
| 7 | EYENUT, 3/4" | 2 | TITLE TANGENT DOUBLE DEAD-END |
| 8 | INSULATOR, POLYMER DEAD-END TYPE (25kV) | 2 | |
| 9 | THIMBLE CLEVIS, HENDRIX CATALOG NO. TC | 2 | DRAWING NO. REV AC1194-02 0 |
| 10 | INSULATOR, PIN TYPE, HENDRIX HPI-25VTP | 1 | |
| 11 | INSULATOR PIN, HENDRIX SSP-2 | 1 | DATE 3/3/15 |
| 12 | MESSENGER BRACKET, HENDRIX TYPE BM-14 | 1 | |
| 13 | MACHINE BOLT, 5/8" X REQ. LENGTH | 2 |  AERIAL CABLE SYSTEMS 53 OLD WILTON RD. • MILFORD, NH 03055 • 603-673-2040 |
| 14 | CONNECTORS, (SIZE AND TYPE AS REQ.) | 4 | |
| 15 | SHACKLE CLEVIS, HENDRIX CATALOG NO. SC | 2 | |
| 16 | GROUND WIRE, SOFT DRAWN COPPER, SOLID, #6 AWG MIN | AS REQ | |
| 17 | GROUND WIRE STAPLE | AS REQ | |
| 18 | SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16" MIN | 6 | |
| 19 | POLE EYE PLATE | 2 | |
| 20 | MACHINE BOLT, 3/4" X REQ LENGTH | 4 | |
| 21 | FIBERGLASS STRAIN INSULATOR | 2 | |