


ITEMS IN RED NOT SUPPLIED BY HENDRIX

| ITEM | DESCRIPTION  | QTY    | DESIGN PARAMETERS   |
|------|--|--------|---|
| 1    | HENDRIX AERIAL CABLE, (SIZE AND VOLTAGE AS REQ.)       | AS REQ | 25kV<br>CROSS-ARM   |
| 2    | MESSENGER, (SIZE AND TYPE AS REQ.)                     | AS REQ |   |
| 3    | INSULATOR, HENDRIX HPI-25VTP                           | 6      |   |
| 4    | INSULATOR PIN, LONG SHANK HENDRIX TYPE LSP-1           | 6      | TITLE   |
| 5    | PRESHAPED CONDUCTOR GRIP, COATED                       | 3      | DEAD-END TRANSITION:<br>SPACER CABLE TO BARE WIRE   |
| 6    | PRESHAPED MESSENGER GRIP                               | 1      | DRAWING NO.                      REV  |
| 7    | INSULATOR, POLYMER DEAD-END TYPE, 25KV                 | 6      | <b>AC1248-02</b> <b>4</b>   |
| 8    | LIGHTNING ARRESTER WITH MOUNTING BRACKET               | 3      | DATE  |
| 9    | THIMBLE CLEVIS, HENDRIX CATALOG NO. TC                 | 3      | 6/18/15   |
| 10   | EYE NUT, STANDARD 3/4"                                 | 6      | <br><b>AERIAL CABLE SYSTEMS</b><br>53 OLD WILTON RD. • MILFORD, NH 03055 • 603-673-2040 |
| 11   | DOUBLE ARMING BOLT, 3/4" X REQ. LENGTH                 | 4      |   |
| 12   | GROUND WIRE, SOFT DRAWN COPPER, SOLID, #6 AWG MIN.     | AS REQ |   |
| 13   | GROUND WIRE STAPLES                                    | AS REQ |   |
| 14   | CONNECTOR, (SIZE AND TYPE AS REQ.)                     | 3      |   |
| 15   | FIBERGLASS STRAIN INSULATOR, CONTINENTAL NO. GCC21-36R | 1      |   |
| 16   | GROOVE CLAMP, SIZE AND TYPE AS REQ.                    | 3      |   |
| 17   | DEAD-END BARE WIRE CLAMP                               | 3      |   |
| 18   | EYE BOLT, 3/4" X REQ. LENGTH                           | 1      |   |
| 19   | THIMBLE CLEVIS, HEAVY DUTY, HENDRIX CAT NO. HDTC       | 1      |   |
| 20   | SHACKLE CLEVIS, HENDRIX CAT NO. SC                     | 6      |   |
| 21   | MACHINE BOLTS, 3/4" X REQ. LENGTH                      | 2      |   |