



ITEM	HENDRIX PART NUMBER	DESCRIPTION	QTY
1	POLE-XX	POLE (TYPE, CLASS & LENGTH AS REQ.)	1
2	SC-VC5.21	25kV, 3-PHASE PRIMARY DOUBLE SUPPORT - SINGLE DEADEND	1
2.1	HDTC	THIMBLE CLEVIS - 40,000 LBS.	1
2.2	MG-0000	PREFORMED GRIP, MESSENGER (SIZE & KIND AS REQ.)	1
2.3	DEINS25	INSULATOR - DEAD END, 25kV	3
2.4	TC	CLEVIS - THIMBLE	3
2.5	CG-0000	PREFORMED GRIP, CONDUCTORS, COATED (SIZE & KIND AS REQ.)	3
2.6	XARM-8FT	CROSSARM, 3-5/8 X 4-5/8 X 8'-0"	2
2.7	BRACE-28IN	BRACE, 28"	4
2.8	EBLT3/4	BOLT, EYE, 3/4" X REQ. LENGTH	1
2.9	DABLT5/8	BOLT, DOUBLE ARMING, 5/8" X REQ. LENGTH	3
2.10	CBLT3/8	BOLT, CARRIAGE, 3/8 X 4-1/2"	4
2.11	LSCREW1/2X4	SCREW, LAG, 1/2 X 4"	2
2.12	SWSH5/8	WASHER, SQUARE, 5/8 X 2-1/4"	10
2.13	SWSH3/4	WASHER, SQUARE, 3/4 X 2-1/4"	2
2.14	LWSH5/8	WASHER, SPRINGLOCK, 5/8"	10
2.15	LWSH3/4	WASHER, SPRINGLOCK, 3/4"	1
2.16	LNUT3/8	LOCKNUT, 3/8"	4
2.17	LNUT5/8	LOCKNUT, 5/8"	7
2.18	LNUT3/4	LOCKNUT, 3/4"	1
2.19	ENUT5/8	NUT, EYE, 5/8"	3
3	SC-U.03G	3-PHASE PRIMARY TRANSITION OR TAP TO UNDERGROUND RISER GUIDE	1
3.1	LINEDUC-00	LINE-DUC 8' SECTION (COLOR AS REQ.)	1
3.2	TAPO0CUSXX	TAP WIRE, COVERED, 6' LENGTH (SIZE AS REQ.), CUT TO SUIT	AS REQ
3.3	MOUNT-XX	EQUIPMENT MOUNT (TYPE AS REQ.)	1
3.4	CUTOUT-XX	FUSED CUTOUT (TYPE & VOLTAGE RATING AS REQ.)	3
3.5	MOUNT-XX	EQUIPMENT MOUNT (TYPE AS REQ.)	1
3.6	URDTERM-XX	TERMINATOR, UNDERGROUND CABLE (TYPE & RATING AS REQ.)	3
3.7	ARRESTER-XX	LIGHTNING ARRESTER (TYPE & RATING AS REQ.)	3
4	SC-H.01G	GROUNDING GUIDE SPACER CABLE	1
4.1	GNDWIRE-XX	GROUNDWIRE, COPPER, #6 AWG (MIN) (LENGTH AS REQ.)	AS REQ
4.2	CONNECTOR-XX	CONNECTOR (SIZE & TYPE AS REQUIRED)	AS REQ
4.3	STAPLE-XX	GROUND WIRE STAPLE (SIZE & TYPE AS REQUIRED)	AS REQ
4.4	GNDASSY-XX	GROUND ASSEMBLY (TYPE AS REQ., NOT SHOWN)	1
5	SC-E.01G	GUYING GUIDE, SPACER CABLE	1
5.1	POLEEYE-XX	POLE-EYE PLATE (SIZE AND STRENGTH AS REQUIRED)	1
5.2	GUYSTRAIN-XX	GUY STRAIN (SIZE & TYPE AS REQUIRED)	1
5.3	GUYSTRAND-XX	GUY STRAND (SIZE AND TYPE AS REQUIRED)	AS REQ
5.4	ANCHORASSY-XX	ANCHOR AND ANCHOR ROD (SIZE AND TYPE AS REQUIRED)	1

RED ITEMS ARE NOT SUPPLIED BY HENDRIX



AERIAL CABLE SYSTEMS

53 OLD WILTON RD. ■ MILFORD, NH 03055 ■ (603) 673-2040

DESIGN PARAMETERS:

KV CLASS: 25kV

LINE ANGLE: 0°

REVISION: 0

25KV, 3-PHASE PRIMARY
DEADEND CROSSARM (WOOD)
WITH 3-PHASE UNDERGROUND RISER

DRAWING NO.:
AC1289-02