



ITEMS IN RED NOT SUPPLIED BY HENDRIX

ITEM	DESCRIPTION	QTY	DESIGN PARAMETERS
1	HENDRIX AERIAL CABLE, (SIZE AND VOLTAGE AS REQ.)	AS REQ	35kV
2	MESSENGER, (SIZE AND TYPE AS REQ.)	AS REQ	BUCK ARM DOUBLE CROSS-ARM CONSTRUCTION
3	INSULATOR, PIN TYPE, HENDRIX HPI-35VTP	6	
4	INSULATOR PIN, HENDRIX TYPE LSP-1	6	
5	PRESHAPED CONDUCTOR GRIP, COATED	3	
6	PRESHAPED MESSENGER GRIP	1	
7	INSULATOR, POLYMER DEAD-END HENDRIX DEINS15	6	
8	HEAVY DUTY THIMBLE CLEVIS, HENDRIX HDTC	1	
9	THIMBLE CLEVIS, CATALOG NO. TC	3	TITLE
10	EYE NUT, STANDARD 3/4"	6	BUCK ARM DOUBLE DEAD-END TRANSITION
11	DOUBLE ARMING BOLT, 3/4" X REQ. LENGTH	6	SPACER CABLE TO BARE
12	GROUND WIRE, SOFT DRAWN COPPER, SOLID, #6 AWG MIN.	AS REQ	DRAWING NO.
13	GROUND WIRE STAPLE	AS REQ	REV
14	CONNECTOR, (SIZE AND TYPE AS REQ.)	3	AC1307-03
15	FIBERGLASS STRAIN INSULATOR	1	DATE
16	POLE EYE PLATE	2	6/26/14
17	EYE BOLT, 3/4" X REQ. LENGTH	1	
18	DEAD-END BARE WIRE CLAMP	3	
19	SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16" MIN	20	
20	MACHINE BOLT, 3/4" X REQ. LENGTH	6	
21	PARALLEL GROOVE CLAMP	3	
22	CROSS-ARM, 8FT LONG	4	
23	LIGHTNING ARRESTER WITH MOUNTING BRACKET	3	



53 OLD WILTON RD. • MILFORD, NH 03055 • 603-673-2040