



ITEM	HENDRIX PART NUMBER	DESCRIPTION	QTY
1	POLE-XX	POLE (TYPE, CLASS & LENGTH AS REQ.)	1
2	SC-ZA5.1	35-46kV, 1-PHASE PRIMARY - SINGLE DEADEND	1
2.1	HDC	THIMBLE CLEVIS - 40,000 LBS.	1
2.2	MG-0000	PREFORMED GRIP, MESSENGER (SIZE & KIND AS REQ.)	1
2.3	DEINS35	INSULATOR - DEAD END, 35kV	1
2.4	TC	CLEVIS - THIMBLE	1
2.5	CG-0000	PREFORMED GRIP, CONDUCTORS, COATED (SIZE & KIND AS REQ.)	1
2.6	LINEDUC-00	LINE-DUC 8' SECTION (COLOR AS REQ.)	1
2.6	EBLT5/8-XX	BOLT, EYE, 5/8" X REQ. LENGTH	2
2.7	SWSH5/8-XX	WASHER, SQUARE, 5/8 X 2-1/4"	4
2.8	LWSH5/8-XX	WASHER, SPRINGLOCK, 5/8"	2
2.9	SNUT5/8-XX	SQUARE NUT, 5/8"	2
3	SC-P.01G	1-PHASE LIGHTNING ARRESTER GUIDE	1
3.1	ARRESTER-XX	LIGHTNING ARRESTER (TYPE & RATING AS REQ.)	1
3.2	STANDOFF-XX	BRACKET - STANDOFF (SIZE & KIND AS REQ)	1
3.3	TAP00CUSXX	TAP WIRE, COVERED (SIZE AS REQ.), CUT TO SUIT	1
3.4	CONNECTOR-XX	CONNECTOR (SIZE & TYPE AS REQUIRED)	1
4	SC-E.01G	GUYING GUIDE, SPACER CABLE	1
4.1	POLEEYE-XX	POLE-EYE PLATE (SIZE AND STRENGTH AS REQUIRED)	1
4.2	GUYSTRAIN-XX	GUY STRAIN (SIZE & TYPE AS REQUIRED)	1
4.3	GUYSTRAND-XX	GUY STRAND (SIZE AND TYPE AS REQUIRED)	1
4.4	ANCHORASSY-XX	ANCHOR AND ANCHOR ROD (SIZE AND TYPE AS REQUIRED)	1
5	SC-H.01G	GROUNDING GUIDE SPACER CABLE	1
5.1	GNDWIRE-XX	GROUNDWIRE, COPPER, #6 AWG (MIN) (LENGTH AS REQ.)	1
5.2	CONNECTOR-XX	CONNECTOR (SIZE & TYPE AS REQUIRED)	2
5.3	STAPLE-XX	GROUND WIRE STAPLE (SIZE & TYPE AS REQUIRED)	1
5.4	GNDASSY-XX	GROUND ASSEMBLY (TYPE AS REQ., NOT SHOWN)	1

RED ITEMS ARE NOT SUPPLIED BY HENDRIX

**Hendrix**<sup>®</sup>  
AERIAL CABLE SYSTEMS

53 OLD WILTON RD. ■ MILFORD, NH 03055 ■ (603) 673-2040

DESIGN PARAMETERS:

KV CLASS: 35-46kV

LINE ANGLE: 0°

REVISION: 0

35-46KV, 1-PHASE PRIMARY  
DEADEND

DRAWING NO.:

AC1193-03