



ITEM	HENDRIX PART NUMBER	DESCRIPTION	QTY
1	POLE-XX	POLE (TYPE, CLASS & LENGTH AS REQ.)	1
2	SC-C1.2	15KV, 3-PHASE PRIMARY - TANGENT WITH ANTI-SWAY BRACKET	1
2.1	BM-14	BRACKET - TANGENT MESSENGER, 14"	1
2.2	BAS-14F	BRACKET - ANTI - SWAY, 14"	1
2.3	TS-1	STIRRUP - TANGENT BRACKET	1
2.4	RTL-15	SPACER - 3 PHASE, 15KV	1
2.5	MBLT3/4	BOLT, MACHINE, 3/4" X REQ. LENGTH	2
2.6	SWSH3/4	WASHER, SQUARE, 3/4 X 2-1/4"	2
2.7	LWSH3/4	WASHER, SPRINGLOCK, 3/4"	2
2.8	LNUT3/4	LOCKNUT, 3/4"	2
2.9	LSCREW1/2X4	SCREW, LAG, 1/2 X 4"	1
3	SC-G1.01	1-PHASE PRIMARY TAP TO SINGLE CONVENTIONAL TRANSFORMER	1
3.1	LINEDUC-00	LINE-DUC 8' SECTION (COLOR AS REQ.)	1
3.2	WG100-01	GUARD, TRANSFORMER BUSHING	1
3.3	TRANSFORMER-XX	TRANSFORMER, SINGLE PHASE (KVA AND VOLTAGE RATING AS REQ.)	1
3.4	MOUNT-XX	EQUIPMENT MOUNT (TYPE AS REQ.)	1
3.5	CUTOFF-XX	FUSED CUTOFF (TYPE & VOLTAGE RATING AS REQ.)	1
3.6	TAPCLAMP-XX	TAP CLAMP (SIZE & TYPE AS REQ.)	1
3.7	TAP00CUSXX	TAP WIRE, COVERED, 6' LENGTH (SIZE AS REQ.), CUT TO SUIT	AS REQ
4	SC-H.01G	GROUNDING GUIDE SPACER CABLE	1
4.1	GNDWIRE-XX	GROUND WIRE, COPPER, #6 AWG (MIN) (LENGTH AS REQ.)	AS REQ
4.2	CONNECTOR-XX	CONNECTOR (SIZE & TYPE AS REQUIRED)	AS REQ
4.3	STAPLE-XX	GROUND WIRE STAPE (SIZE & TYPE AS REQUIRED)	AS REQ
4.4	GNDASSY-XX	GROUND ASSEMBLY (TYPE AS REQ., NOT SHOWN)	1

RED ITEMS ARE NOT SUPPLIED BY HENDRIX



AERIAL CABLE SYSTEMS

53 OLD WILTON RD. ■ MILFORD, NH 03055 ■ (603) 673-2040

DESIGN PARAMETERS:

KV CLASS: 15KV

LINE ANGLE: 0-6°

REVISION: 3

15KV, 3-PHASE PRIMARY
TANGENT
WITH 1-PHASE TRANSFORMER

DRAWING NO.:
AC1243-01