



ITEM	HENDRIX PART NUMBER	DESCRIPTION	QTY
1	POLE-XX	POLE (TYPE, CLASS & LENGTH AS REQ.)	1
2	SC-TC6.1	69KV, 3-PHASE PRIMARY - DOUBLE DEADEND, SPACER CABLE TO BARE WIRE	1
2.1	HDTC	THIMBLE CLEVIS - 40,000 LBS.	1
2.2	MG-0000	PREFORMED GRIP, MESSENGER (SIZE & KIND AS REQ.)	1
2.3	GUYINSULATOR-10	STRAIN INSULATOR, GUY, CLEVIS-THIMBLE EYE, 36" LNG, 15,000 LB	3
2.4	DEINS69	INSULATOR - DEAD END, 69kV	3
2.5	TC	CLEVIS - THIMBLE	3
2.6	CG-0000	PREFORMED GRIP, CONDUCTORS, COATED (SIZE & KIND AS REQ.)	3
2.7	LP-INS-3	LINE POST INSULATOR, 69KV	3
2.8	TRUNNION-01	CLAMP - TRUNNION, FOR LINE POST INSULATORS	3
2.9	SINS69-XX	STRAIN INSULATOR, 69KV (SIZE & TYPE AS REQ.)	3
2.10	DECLAMP-XX	DEAD-END CLAMP FOR BARE WIRE (SIZE & TYPE AS REQ.)	3
2.11	PGCLAMP-XX	PARALLEL GROOVE CLAMP (TYPE & SIZE AS REQ.)	3
2.12	TR-ARRESTER-XX	LIGHTNING ARRESTER, TRANSMISSION (TYPE & RATING AS REQ.)	3
2.13	MLBT3/4-XX	BOLT, MACHINE, 3/4" X REQ. LENGTH	6
2.14	EBLT3/4-XX	BOLT, EYE, 3/4" X REQ. LENGTH	7
2.15	SWSH3/4-XX	WASHER, SQUARE, 3/4 X 2-1/4"	14
2.16	LWSH3/4-XX	WASHER, SPRINGLOCK, 3/4"	13
2.17	SNUT3/4-XX	SQUARE NUT, 3/4"	13
3	SC-E.01G	GUYING GUIDE, SPACER CABLE	2
3.1	POLEEYE-XX	POLE-EYE PLATE (SIZE AND STRENGTH AS REQUIRED)	1
3.2	GUYSTRAIN-XX	GUY STRAIN (SIZE & TYPE AS REQUIRED)	1
3.3	GUYSTRAND-XX	GUY STRAND (SIZE AND TYPE AS REQUIRED)	AS REQ
3.4	ANCHORASSY-XX	ANCHOR AND ANCHOR ROD (SIZE AND TYPE AS REQUIRED)	1
4	SC-H.01G	GROUNDING GUIDE SPACER CABLE	1
4.1	GNDWIRE-XX	GROUNDWIRE, COPPER, #6 AWG (MIN) (LENGTH AS REQ.)	AS REQ
4.2	CONNECTOR-XX	CONNECTOR (SIZE & TYPE AS REQUIRED)	2
4.3	STAPLE-XX	GROUND WIRE STAPLE (SIZE & TYPE AS REQUIRED)	AS REQ
4.4	GNDASSY-XX	GROUND ASSEMBLY (TYPE AS REQ., NOT SHOWN)	1

RED ITEMS ARE NOT SUPPLIED BY HENDRIX



AERIAL CABLE SYSTEMS

53 OLD WILTON RD. ■ MILFORD, NH 03055 ■ (603) 673-2040

DESIGN PARAMETERS:

KV CLASS: 69KV

LINE ANGLE: 0-6°

REVISION: 1

69KV, 3-PHASE PRIMARY
DEADEND
BARE WIRE TO SPACER CABLE

DRAWING NO.:
AC1262-05