



ITEMS IN RED NOT SUPPLIED BY HENDRIX

ITEM	DESCRIPTION	QTY	DESIGN PARAMETERS
1	MESSENGER BRACKET, HENDRIX TYPE BM-14	1	15kV
2	ANGLE BRACKET, HENDRIX TYPE BA3-15	1	LINE ANGLES: 0-6°
3	INSULATOR, PIN TYPE, HENDRIX HPI-15VTP	3	TITLE
4	INSULATOR PIN, HENDRIX SSP-2	3	TANGENT CONSTRUCTION WITH BA3-15
5	HENDRIX AERIAL CABLE,(SIZE AND VOLTAGE RATING AS REQ.)	AS REQ	DRAWING NO. REV
6	MESSENGER, (SIZE AND TYPE AS REQUIRED)	AS REQ	AC1277-01 1
7	CONNECTOR, (SIZE AND TYPE AS REQ.)	2	DATE
8	GROUND WIRE, SOFT DRAWN COPPER, SOLID #6 AWG	AS REQ	2/19/16
9	GROUND WIRE STAPLE	AS REQ	
10	MACHINE BOLT, 5/8" X REQ. LENGTH	4	
11	SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16" (MIN)	4	



53 OLD WILTON RD. • MILFORD, NH 03055 • 603-673-2040