



ITEM	HENDRIX PART NUMBER	DESCRIPTION	QTY
1	POLE-XX	POLE (TYPE, CLASS & LENGTH AS REQ.)	1
2	SC-VC6.23	25KV, 3-PHASE PRIMARY DOUBLE SUPPORT - DOUBLE DEADEND TANGENT MESSENGER, ON DOUBLE CROSSARMS	1
2.1	BM-24	BRACKET - TANGENT MESSENGER, 24"	1
2.2	DEINS25	INSULATOR - DEAD END, 25KV	6
2.3	TC	CLEVIS - THIMBLE	6
2.4	CG-0000	PREFORMED GRIP, CONDUCTORS, COATED (SIZE & KIND AS REQ.)	6
2.5	XARM-8FT-XX	CROSSARM, 3-5/8 X 4-5/8 X 8'-0"	2
2.6	BRACE-28IN-XX	BRACE, 28"	4
2.7	DABLT5/8-XX	BOLT, DOUBLE ARMING, 5/8" X REQ. LENGTH	4
2.8	LSCRW1/2X4-XX	SCREW, LAG, 1/2 X 4"	2
2.9	CBLT3/8X4-1/2-XX	BOLT, CARRIAGE, 3/8 X 4-1/2"	4
2.10	MBLT3/4-XX	BOLT, MACHINE, 3/4" X REQ. LENGTH	2
2.11	SWSH5/8-XX	WASHER, SQUARE, 5/8 X 2-1/4"	14
2.12	SWSH3/4-XX	WASHER, SQUARE, 3/4 X 2-1/4"	2
2.13	LWSH5/8-XX	WASHER, SPRINGLOCK, 5/8"	8
2.14	LWSH3/4-XX	WASHER, SPRINGLOCK, 3/4"	2
2.15	ENUT5/8-XX	NUT, EYE, 5/8"	6
2.16	LNUT3/8-XX	LOCKNUT, 3/8"	4
2.17	SNUT5/8-XX	SQUARE NUT, 5/8"	8
2.18	SNUT3/4-XX	SQUARE NUT, 3/4"	2
3	SC-P.03G	3-PHASE LIGHTNING ARRESTER GUIDE SPACER CABLE	1
3.1	ARRESTER-XX	LIGHTNING ARRESTER (TYPE & RATING AS REQ.)	3
3.2	TAP00CUSXX	TAP WIRE, COVERED (SIZE AS REQ.), CUT TO SUIT	AS REQ
4	SC-H.01G	GROUNDING GUIDE SPACER CABLE	1
4.1	GNDWIRE-XX	GROUND WIRE, COPPER, #6 AWG (MIN) (LENGTH AS REQ.)	AS REQ
4.2	CONNECTOR-XX	CONNECTOR (SIZE & TYPE AS REQUIRED)	AS REQ
4.3	STAPLE-XX	GROUND WIRE STAPLE (SIZE & TYPE AS REQUIRED)	AS REQ
4.4	GNDASSY-XX	GROUND ASSEMBLY (TYPE AS REQ., NOT SHOWN)	1
5	MOUNT-XX	EQUIPMENT MOUNT (TYPE AS REQ.)	1
6	PRMRY-EQUIP-XX	PRIMARY EQUIPMENT (TYPE, RATING AS REQ'D)	3
7	LINEDUC-00	LINE-DUC 8" SECTION (COLOR AS REQ.)	2

RED ITEMS ARE NOT SUPPLIED BY HENDRIX



AERIAL CABLE SYSTEMS

53 OLD WILTON RD. ■ MILFORD, NH 03055 ■ (603) 673-2040

DESIGN PARAMETERS:

KV CLASS: 25KV

LINE ANGLE: 0-6°

REVISION: 0

25KV, 3-PHASE PRIMARY
DOUBLE DEADEND CROSSARM (WOOD)
WITH 3-PHASE EQUIPMENT TAP

DRAWING NO.:
AC1293-02