



ITEM	HENDRIX PART NUMBER	DESCRIPTION	QTY
1	POLE-XX	POLE (TYPE, CLASS & LENGTH AS REQ.)	1
2	SC-ZC1.42	35-46KV, 3-PHASE PRIMARY SINGLE SUPPORT - TANGENT	1
2.1	BM-24	BRACKET - TANGENT MESSENGER, 24"	1
2.2	HPI-35VTP-01	INSULATOR, 35KV VISE TOP, 1" PIN	3
2.3	LSP-1	INSULATOR PIN - LONG SHANK, 3/4" W/ 1" NYLON THREAD	3
2.4	CROSSARM-XX	CROSSARM ASSEMBLY (TYPE AND SIZE AS REQ.)	1
2.5	MBLT5/8-XX	BOLT, MACHINE, 5/8" X REQ. LENGTH	2
2.6	LWSH5/8-XX	WASHER, SPRINGLOCK, 5/8"	2
2.7	SNUT5/8-XX	SQUARE NUT, 5/8"	2
2.8	SWSH5/8-XX	WASHER, SQUARE, 5/8 X 2-1/4"	2
2.9	MLBT3/4-XX	BOLT, MACHINE, 3/4" X REQ. LENGTH	2
2.10	LWSH3/4-XX	WASHER, SPRINGLOCK, 3/4"	2
2.11	SNUT3/4-XX	SQUARE NUT, 3/4"	2
2.12	SWSH3/4-XX	WASHER, SQUARE, 3/4 X 2-1/4"	2
3	SC-H.01G	GROUNDING GUIDE SPACER CABLE	1
3.1	STAPLE-XX	GROUND WIRE STAPLE (SIZE & TYPE AS REQUIRED)	1
3.2	CONNECTOR-XX	CONNECTOR (SIZE & TYPE AS REQUIRED)	2
3.3	GNDWIRE-XX	GROUND WIRE, COPPER, #6 AWG (MIN) (LENGTH AS REQ.)	1
3.4	GNDASSY-XX	GROUND ASSEMBLY (TYPE AS REQ., NOT SHOWN)	1

RED ITEMS ARE NOT SUPPLIED BY HENDRIX



AERIAL CABLE SYSTEMS

53 OLD WILTON RD. ■ MILFORD, NH 03055 ■ (603) 673-2040

DESIGN PARAMETERS:

KV CLASS: 35-46kV

LINE ANGLE: 0-6°

GO95 COMPLIANT

REVISION: 0

35-46KV, 3-PHASE PRIMARY
TANGENT

DRAWING NO.:

CROSSARM (WOOD) WITH 1-PHASE LATERAL TAP

AC1299-03