


ITEMS IN RED NOT SUPPLIED BY HENDRIX

ITEM	DESCRIPTION	QTY	DESIGN PARAMETERS
1	HENDRIX AERIAL CABLE, (SIZE AND VOLTAGE AS REQ.)	AS REQ	35kV
2	MESSENGER, (SIZE AND TYPE AS REQ.)	AS REQ	BUCK ARM DOUBLE CROSS-ARM CONSTRUCTION
3	INSULATOR, PIN TYPE, HENDRIX HPI-35VTP	6	TITLE
4	INSULATOR PIN, HENDRIX TYPE LSP-1	6	BUCK ARM DOUBLE DEAD-END TRANSITION
5	PRESHAPED CONDUCTOR GRIP, COATED	6	SPACER CABLE TO SPACER CABLE
6	PRESHAPED MESSENGER GRIP	2	DRAWING NO. REV
7	INSULATOR, POLYMER DEAD-END HENDRIX DEINS35	6	AC1311-03 0
8	HEAVY DUTY THIMBLE CLEVIS, HENDRIX HDTC	2	DATE
9	THIMBLE CLEVIS, CATALOG NO. TC	6	3/14/16
10	EYE NUT, STANDARD 3/4"	6	 53 OLD WILTON RD. • MILFORD, NH 03055 • 603-673-2040
11	DOUBLE ARMING BOLT, 3/4" X REQ. LENGTH	6	
12	GROUND WIRE, SOFT DRAWN COPPER, SOLID, #6 AWG MIN.	AS REQ	
13	GROUND WIRE STAPLE	AS REQ	
14	CONNECTOR, (SIZE AND TYPE AS REQ.)	2	
15	FIBERGLASS STRAIN INSULATOR	1	
16	POLE EYE PLATE	2	
17	EYE BOLT, 3/4" X REQ. LENGTH	2	
18	SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16" MIN	20	
19	MACHINE BOLT, 3/4" X REQ. LENGTH	6	
20	CROSS-ARM, 8FT LONG	4	