



ITEM	HENDRIX PART NUMBER	DESCRIPTION	QTY
1	POLE-XX	POLE (TYPE, CLASS & LENGTH AS REQ.)	1
2	HDTC	THIMBLE CLEVIS - 40,000 LBS.	2
3	MG-0000	PREFORMED GRIP, MESSENGER (SIZE & KIND AS REQ.)	2
4	MESSENGER	MESSENGER (SIZE & TYPE AS REQ.)	2
5	LP-INS-115M	INSULATOR, LINE-POST, 115KV, TYPE 58	3
6	RCC-HV	ROTATED CLEVIS/CLEVIS, 0.625", 30000LBS	3
7	MTC-HV	CLAMP, HIGH VOLTAGE, 115KV	3
8	TIHV-0000	INSERT, TRUNNION, HIGH VOLTAGE (SIZE AS REQ)	6
9	SC	CLEVIS - SHACKLE	6
10	DEINS115	INSULATOR, POLYMER DEAD END, 115KV	6
11	TC	CLEVIS - THIMBLE	6
12	EBLT7/8-XX	BOLT, EYE, 7/8" X REQ. LENGTH	6
13	MBLT7/8	BOLT, MACHINE, 7/8" X REQ. LENGTH	10
14	SNUT7/8-XX	SQUARE NUT, 7/8"	16
15	CG-0000	PREFORMED GRIP, CONDUCTORS, COATED (SIZE & KIND AS REQ.)	6
16	GUYINSULATOR-10	STRAIN INSULATOR, GUY, CLEVIS-THIMBLE EYE, 36" LNG, 15,000 LB	6
17	WSH7/8-XX	WASHER, LOCK, 7/8"	16
18	CONNECTOR-XX	GROUND CONNECTOR - PARALLEL GROOVE	1
19	DEAD-END-TEE-01	DEAD-END TEE	2
20	GNDWIRE-XX	GROUND WIRE, COPPER, #6 AWG (MIN) (LENGTH AS REQ)	AS REQ
21	GROUNDPOST-01	GROUND CONNECTOR - POST TYPE	1

RED ITEMS ARE NOT SUPPLIED BY HENDRIX

Hendrix[®]
AERIAL CABLE SYSTEMS

53 OLD WILTON RD. ■ MILFORD, NH 03055 ■ (603) 673-2040

DESIGN PARAMETERS:

KV CLASS: 115KV

LINE ANGLE: 7-60°

REVISION: 1

115KV, 3-PHASE PRIMARY
DOUBLE DEADEND
VERTICAL CONFIGURATION

DRAWING NO.:
AC1503-06