



RED ITEMS ARE NOT SUPPLIED BY HENDRIX

ITEM	HENDRIX PART NUMBER	DESCRIPTION	QTY
1	POLE-XX	POLE (TYPE, CLASS & LENGTH AS REQ.)	1
2	HDTC	THIMBLE CLEVIS - 40,000 LBS.	2
3	MG-0000	PREFORMED GRIP, MESSENGER (SIZE & KIND AS REQ.)	2
4	CG-0000	PREFORMED GRIP, CONDUCTORS, COATED (SIZE & KIND AS REQ.)	6
5	MESSENGER	MESSENGER (SIZE & TYPE AS REQ.)	2
6	SC	CLEVIS - SHACKLE	6
7	DEINS115	INSULATOR, POLYMER DEAD END, 115kV	6
8	TC	CLEVIS - THIMBLE	6
9	LP-INS-115M	INSULATOR, LINE-POST, 115KV, TYPE 58	3
10	RCC-HV	ROTATED CLEVIS/CLEVIS, 0.625", 30000LBS	3
11	MTC-HV	CLAMP, HIGH VOLTAGE, 115KV	3
12	TIHV-0000	INSERT, TRUNNION, HIGH VOLTAGE (SIZE AS REQ)	6
13	MBLT7/8-XX	BOLT, MACHINE, 7/8" X REQ. LENGTH	8
14	SNUT7/8-XX	SQUARE NUT, 7/8"	14
15	EBLT7/8-XX	BOLT, EYE, 7/8" X REQ. LENGTH	6
16	GUYINSULATOR-10	STRAIN INSULATOR, GUY, CLEVIS-THIMBLE EYE, 36" LNG, 15,000 LB	6
17	CONNECTOR-XX	GROUND CONNECTOR - PARALLEL GROOVE	1
18	GNDWIRE-XX	GROUND WIRE, COPPER, #6 AWG (MIN) (LENGTH AS REQ)	AS REQ
19	DEAD-END-TEE-01	DEAD-END TEE	2
20	WSH7/8-XX	WASHER, LOCK, 7/8"	14
21	GROUNDPOST-01	GROUND CONNECTOR - POST TYPE	1

Hendrix[®]
 AERIAL CABLE SYSTEMS
 DETAIL A

53 OLD WILTON RD. ■ MILFORD, NH 03055 ■ (603) 673-2040

DESIGN PARAMETERS:
 KV CLASS: 115kV
 LINE ANGLE: 0-6°

REVISION: 1

115KV, 3-PHASE PRIMARY
 DOUBLE DEADEND
 VERTICAL CONFIGURATION

DRAWING NO.:
AC1505-06