



ITEM	HENDRIX PART NUMBER	DESCRIPTION	QTY
1	POLE-XX	POLE (TYPE, CLASS & LENGTH AS REQ.)	1
2	HDTC	THIMBLE CLEVIS - 40,000 LBS.	1
3	MG-0000	PREFORMED GRIP, MESSENGER (SIZE & KIND AS REQ.)	1
4	MESSENGER	MESSENGER (SIZE & TYPE AS REQ.)	1
5	CG-0000	PREFORMED GRIP, CONDUCTORS, COATED (SIZE & KIND AS REQ.)	3
6	LP-INS-115M	INSULATOR, LINE-POST, 115KV, TYPE 58	3
7	RCC-HV	ROTATED CLEVIS/CLEVIS, 0.625", 30000LBS	3
8	MTC-HV	CLAMP, HIGH VOLTAGE, 115KV	3
9	TIHV-0000	INSERT, TRUNNION, HIGH VOLTAGE (SIZE AS REQ)	6
10	SC	CLEVIS - SHACKLE	6
11	DEINS115	115KV DEAD END INSULATOR	3
12	TR-DEINS-XX	DEAD END INSULATOR, TRANSMISSION (TYPE AND RATING AS REQ)	3
13	TC	CLEVIS - THIMBLE	6
14	TR-ARRESTER-XX	LIGHTNING ARRESTER, TRANSMISSION (TYPE & RATING AS REQ.)	3
15	MBLT7/8	BOLT, MACHINE, 7/8" X REQ. LENGTH	8
16	SNUT7/8-XX	SQUARE NUT, 7/8"	14
17	EBLT7/8-XX	BOLT, EYE, 7/8" X REQ. LENGTH	6
18	GUYINSULATOR-10	STRAIN INSULATOR, GUY, CLEVIS-THIMBLE EYE, 36" LNG, 15,000 LB	6
19	PGCLAMP-XX	PARALLEL GROOVE CLAMP (TYPE & SIZE AS REQ.)	3
20	DECLAMP-XX	DEAD-END CLAMP FOR BARE WIRE (SIZE & TYPE AS REQ.)	3
21	DEAD-END-TEE-01	DEAD-END TEE	1
22	WSH7/8-XX	WASHER, LOCK, 7/8"	14
23	CONNECTOR-XX	GROUND CONNECTOR - PARALLEL GROOVE	1
24	GNDWIRE-XX	GROUND WIRE, COPPER, #6AWG (MIN) (LENGTH AS REQ)	AS REQ
25	GROUNDPOST-01	GROUND CONNECTOR - POST TYPE	4

RED ITEMS ARE NOT SUPPLIED BY HENDRIX

Hendrix[®]
AERIAL CABLE SYSTEMS

53 OLD WILTON RD. ■ MILFORD, NH 03055 ■ (603) 673-2040

DESIGN PARAMETERS:

KV CLASS: 115kV

LINE ANGLE: 0-6°

REVISION: 0

115KV, 3-PHASE PRIMARY
BEAR TRANSITION
VERTICAL CONFIGURATION

DRAWING NO.:
AC1507-06